

CHAPTER 53. EVAPORATIVE COOLING

EVAPORATIVE cooling is energy-efficient, environmentally friendly, and cost-effective in many applications and all climates. Applications range from comfort cooling in residential, agricultural, commercial, and institutional buildings, to industrial applications for spot cooling in mills, foundries, power plants, and other hot indoor environments. Several types of apparatus cool by evaporating water directly in the airstream, including (1) direct evaporative coolers, (2) spray-filled and wetted-surface air washers, (3) sprayed-coil units, and (4) humidifiers. Indirect evaporative cooling equipment combines the evaporative cooling effect in a secondary airstream with a heat exchanger to produce cooling without adding moisture to the primary airstream.

Direct evaporative cooling reduces the dry-bulb (db) temperature and increases the relative humidity of the air. It is most commonly applied to dry climates or to applications requiring high air exchange rates. Innovative schemes combining evaporative cooling with refrigeration equipment have resulted in energy-efficient designs with improved indoor air quality (IAQ) (Scofield and Sterling 1992).

When temperature and/or humidity must be controlled within narrow limits, heat and mechanical refrigeration can be combined with evaporative cooling in stages. Evaporative cooling equipment, including unitary equipment and air washers, is covered in [Chapter 41 of the 2020 ASHRAE Handbook—HVAC Systems and Equipment](#).

1. GENERAL APPLICATIONS

Cooling

Evaporative cooling is used in almost all climates. The wet-bulb temperature of the entering airstream limits direct evaporative cooling. The wet-bulb temperature of the secondary airstream limits indirect evaporative cooling.

Design wet-bulb temperatures are rarely higher than 78°F, making direct evaporative cooling economical for spot cooling in kitchens, laundries, agricultural, and industrial applications. In regions with lower wet-bulb temperatures, evaporative cooling can be effectively used for comfort cooling, although some climates may require mechanical refrigeration for part of the year.

Indirect applications lower the air wet-bulb temperature and can produce leaving dry-bulb temperatures that approach the wet-bulb temperature of the secondary airstream. Using building return air as the secondary airstream can further enhance performance of the indirect cooler, especially if the building has a high capacitance for moisture absorption. Incorporating sensible precooled air in the secondary airstream further enhances the indirect evaporative cooler's cooling capability.

Direct evaporative cooling is an adiabatic exchange of energy. Heat must be added to evaporate water in the supply airstream. The air into which water is evaporated supplies the heat; thus, the dry-bulb temperature is lowered and the moisture content increases. The amount of heat removed from the air equals the amount of heat absorbed by the water evaporated as heat of vaporization. If the direct evaporative cooler sump water is recirculated in the direct evaporative cooling apparatus, the water temperature in the reservoir approaches the wet-bulb (wb) temperature of the air entering the process. By definition, no heat is added to, or extracted from, an adiabatic process; the initial and final conditions of the process air fall on a line of constant wet-bulb temperature, which nearly coincides with a line of constant enthalpy on the psychrometric chart ([Figure 1](#)).

The maximum reduction in dry-bulb temperature is the difference between the entering air dry- and wet-bulb temperatures. If air is cooled to the entering air wet-bulb temperature in a direct evaporative cooling process, it becomes saturated and the process would have 100% **wet bulb depression effectiveness (WBDE)**. WBDE is the depression of the dry-bulb temperature in the process divided by the difference between the entering air dry- and wet-bulb conditions.

When a direct evaporative cooling unit alone cannot provide desired conditions, several alternatives can satisfy application requirements and still be energy-effective and economical to operate. The recirculating water supplying the direct evaporative cooling unit can be increased in volume and chilled by mechanical refrigeration to provide lower leaving wet- and dry-bulb temperatures and lower humidity. Compared to the cost of using mechanical refrigeration only, this arrangement reduces operating costs by as much as 25 to 40%. Indirect evaporative cooling applied as a first stage, upstream from a second, direct evaporative stage, reduces both the entering dry- and wet-bulb temperatures before the air enters the direct evaporative cooler. Indirect evaporative cooling may save as much as 60 to 75% or more of the total cost of operating mechanical refrigeration to produce the same cooling effect for 100% outdoor air (OA) systems. Systems may combine indirect evaporative cooling, direct evaporative cooling, heaters, and mechanical refrigeration, in any combination.

The psychrometric chart in [Figure 1](#) shows what happens when air is passed through a direct evaporative cooler. In the example shown, assume an entering condition of 95°F db and 75°F wb. The initial difference is $95 - 75 = 20^\circ\text{F}$. If the effectiveness is 80%, the depression is $0.80 \times 20 = 16^\circ\text{F}$ db. The dry-bulb temperature leaving the direct evaporative cooler is $95 - 16 = 79^\circ\text{F}$. In the adiabatic evaporative cooler, only part of the water recirculated is assumed to evaporate and the water supply is recirculated. The recirculated water reaches an equilibrium temperature approximately the same as the wet-bulb temperature of the entering air.




Figure 1. Psychrometrics of Evaporative Cooling

The performance of an indirect evaporative cooler can also be shown on a psychrometric chart ([Figure 1](#)). Many manufacturers define effectiveness similarly for both direct and indirect evaporative cooling equipment. With indirect evaporative cooling, the cooling process in the primary airstream follows a line of constant moisture content (constant dew point). Indirect evaporative cooling effectiveness is the dry-bulb depression in the primary airstream divided by the difference between the entering dry-bulb temperature of the primary airstream and the entering wet-bulb temperature of the secondary air. Depending on heat exchanger design and relative quantities of primary and secondary air, effectiveness ratings may be as high as 85%.

Assuming 60% effectiveness, and assuming both primary and secondary air enter the apparatus at the outdoor condition of 95°F db and 75°F wb, the dry-bulb depression is $0.60(95 - 75) = 12^\circ\text{F}$. The dry-bulb temperature leaving the indirect evaporative cooling process is $95 - 12 = 83^\circ\text{F}$. Because the process cools without adding moisture, the wet-bulb temperature is also reduced. Plotting on the psychrometric chart shows that the final wet-bulb temperature is 71.5°F. Because both wet- and dry-bulb temperatures in the indirect evaporative cooling process are reduced, indirect evaporative cooling can substitute for part of the refrigeration load in 100% OA systems. This sensible cooling process can make a second-stage direct evaporative cooler more effective in arid climates, because the sensible cooling it contributes allows reduction of mechanical cooling.

VAV Adiabatic Humidification with Heat Recovery Economizer

The health benefits of the humidification offered by a rigid media adiabatic evaporative cooling component are often overlooked. During cold winter conditions, the outdoor air furnished to meet building code ventilation requirements will

quickly drive indoor relative humidity (rh) below acceptable levels.

[Figure 2](#) shows an adiabatic cooler/humidifier (AC/H) rigid media component for the variable-air-volume (VAV) design schematic shown in [Figure 3](#). When selected at a 400 fpm face velocity for full VAV supply fan flow, this device will have a 90% wet bulb depression efficiency (WBDE). At 50% winter VAV supply fan turndown, the WBDE increases to 93%. At these face velocities, nothing but water vapor leaves the wetted rigid media pad. At the low supply fan speed the measured supply air dry bulb (db) will be within 1°F of the supply air dew point (dp) condition at the saturation curve ([Figure 4](#)). Low-cost commercial grade temperature sensors may be used to control relative humidity inside the building various climate zones to maintain the target room 40 to 60% rh.




Figure 2. Adiabatic Evaporative Cooler Humidifier

[Figure 3](#) shows a schematic of an air-handling unit design that provides hydration to dry outdoor air in winter without greatly affecting the building owners heating energy costs. The VAV design concept (Scofield 2020; Taylor et al. 2020) uses a heat wheel air-to-air heat exchanger to recover heat from the building return air both to increase the fresh outdoor air fraction introduced to the building by the economizer dampers and to provide the heat necessary for the evaporation of water for humidification furnished by the adiabatic cooler/humidifier (AC/H). Heat generated inside the building by people, lights, and plug load is recovered through the heat wheel and used to furnish 45°F dp supply air condition to the building. An airflow monitor should be added at damper A in [Figure 3](#) to ensure that ASHRAE *Standard* 62.1 minimum outdoor requirements are met during cold-weather VAV fan turndown.




Figure 3. Schematic of Airflow Through VAV Air-Handling Unit with HRE and AC/H for Winter Hydration of Dry Outdoor Air Supply air to building is 40°F db and approximately 40°F at saturation curve (see Figure 4).

The marriage of an all-outdoor air VAV cooling design to an air-to-air heat exchanger provides significant heating and humidification energy cost savings when compared to the more conventional air side economizer design without heat recovery (Scofield 2020; Taylor et al. 2020). As mass flow through the air-to-air heat exchanger decreases, the heat exchanger becomes more effective. This is also true for the AC/H heat exchanger. When the dwell time in the heat exchanger goes up with VAV turndown, the effectiveness increases and parasitic losses, such as static pressure, are reduced. The heat wheel effectiveness increases from 75% to 87% when VAV turndown is reduced to 50% flow at winter design.

Recent studies have identified low room relative humidity as a factor contributing to the buoyancy, viability and spread of some airborne pathogens within the human breathing zone indoors (Scofield 2020; Taylor et al. 2020). Controlling indoor relative humidity between 40 to 60% at a comfortable room temperature can reduce the risk of human exposure to a number of respiratory infections

Another factor in the spread of pathogens within the human breathing zone indoors is air turbulence. Artificially high room air change rates (ACR) can push airborne contaminants further away from a human host after a cough or sneeze, thereby exposing more healthy humans to infection (Pantelic and Tham 2013).

Reducing a VAV building supply-air temperature set point in cold weather will not only reduce room ACR but also will reduce supply and return fan energy costs for the owner. Core zones will require reheat coils to temper the supply air delivery temperature to the room, but if the VAV box were at its minimum flow setting, there would not be a heating penalty as the minimum flow would match zone code fresh-air requirements. In California, for example, minimum VAV terminal flow settings by code are no less than 0.1 cfm/square foot of floor area in the zone being served. Conversely, high-rise buildings with a high percent of glass exposure on their south-facing perimeter zones will benefit from the 45°F db VAV box supply air temperature to better manage their peak cooling load in winter.

In the cool ambient conditions of spring and fall, when allergies are rampant, the rigid media pads of the AC/H act as an air scrubber with a 90% effectiveness in the removal of pollens in the size range of 5 to 10 μm . This removal of allergens from the outdoor air will improve indoor air quality and reduce sinus and respiratory complaints.

Cold Climate, All-Outdoor-Air VAV With Humidification

Figure 4 shows a psychrometric chart for a cold climate system and the boundaries of ambient climate zones 1, 2, and 3. Assuming a 70°F building return air condition, the sensible heat wheel (Figure 3) with a 87% effectiveness at a 50% supply fan turndown and code-required 25% outdoor air flow would require a 24°F ambient outdoor air temperature to furnish a 40°F dp, db supply air temperature off the AC/H. Ambient temperatures at 23°F or lower would require the preheat coil (Figure 3) addition of heat in order to reach the 40°F wb line in Figure 4. The adiabatic humidifier would then furnish hydration of the outdoor air from 20 to 40°F dp (Figure 4). In Chicago, Illinois, only approximately 8% of the annual hours would require preheat (Table 1). In Chicago, both boilers and chillers are off for 43.3% of the annual hours in climate zone 2. If the VAV supply air set point is allowed to float up from 40°F db, wb, dp to 55°F db, wb, dp at the saturation curve (Figure 4), then another 14.8% of annual hours may be added to the low-cost cooling and humidification design strategy in Chicago.

Table 1 Cold Climate VAC System, Adiabatic Hydration, for All-Outdoor-Air Design Using Air-to-Air Heat Recovery to Minimize Heat Energy

City, State	Elevation, ft	Bin Zone 1 Preheat Required for 100% OA		Bin Zone 2 Humidification without Preheat with 100% OA		Bin Zone 3 Humidification of 100% OA without Heat Recovery, Wet Bulb 40 to 55°F	
		Hours	%	Hours	%	Hours	%
Boise, ID*	2996	225	2.6	4214	48.1	3347	38.2
Chicago, IL	658	692	7.9	36 91	42.1	1885	21.5
Des Moines, ID	938	903	10.3	4399	50.2	1628	18.6
Boston, MA	133	619	7.1	5298	60.5	2064	23.6
Detroit, MI	583	709	8.1	5111	58.3	2526	28.8
Grand Rapids, MI	841	721	8.2	5127	58.5	2428	27.7
St. Paul, MN	834	1404	16.0	4402	50.3	1644	18.8
Billings, MT*	3567	822	9.4	3900	44.5	2868	30.7
Great Falls, MT*	3525	1016	11.6	3981	45.4	3063	35.0
Buffalo, NY	590	520	5.9	5381	61.4	2637	30.1
Bismarck, ND	1647	1772	20.2	3297	37.6	1822	20.8
Grand Forks, ND	911	2138	24.4	2625	30.0	1726	19.7
Cleveland, OH	1208	504	5.8	5144	58.7	2584	29.5
Columbus, OH	824	472	5.4	4634	52.9	2469	28.2
Harrisburg, PA	308	242	2.8	4944	56.4	2678	30.6
Pittsburgh, PA	1137	491	5.6	4940	56.4	2620	29.9
Rapid City, SD*	3276	961	11.0	3657	41.7	2652	30.3
Sioux City, SD	1418	1351	15.4	4405	50.3	2137	24.4
Seattle, WA*	47	18	0.2	2241	25.6	4220	48.2
Spokane, WA*	2462	291	3.3	7744	88.4	3834	43.8
Madison, WI	858	1016	11.6	4799	54.8	2220	25.3
Casper, WY*	5338	827	9.4	3706	42.3	3174	36.2
22 Northern Cities Average			9.19		50.7		29.1

Source: Scofield (2020).

Note: Heat recovery economizer effectiveness is 70% and building return air condition is 70°F. Table gives approximate hours per year, with VAV minimum flow at 25% to maintain indoor conditions between 40 and 60% rh and room temperatures of 70 to 75°F without additional heating beyond heat recovery.

* Cities west of Rocky Mountains and at elevation.

Using local bin weather data, [Table 1](#) shows, for 22 northern U.S. cities, the approximate number of hours per year when both indoor humidification and a delivery dry-bulb condition of 40 to 55°F may be maintained without expenditure of preheat energy. In climate zone 3 ([Figure 4](#)), outdoor air in excess of code-minimum flow is furnished to each VAV terminal box inside the building as ambient temperatures rise. The system modeled would turn down to 25% minimum outdoor flow at winter design and would operate on a 24/7/365 duty cycle. Heat recovery effectiveness would vary from 75% at full flow up to 87% at minimum turndown flow, with 10% less airflow on the exhaust air side of the heat exchanger than on the makeup air side.

Prehumidification and Morning Warm-Up Cycle

The ASHRAE Epidemic Task Force has determined that, holding indoor relative humidity between 40 and 60% is a key factor in the mitigation of the spread of airborne pathogens indoors in any building climate zone, especially in cold winter climates. They also recommend increasing outdoor supply air above the 7.5 cfm per person called for in ASHRAE *Standard* 62.1-2020.




Figure 4. Psychrometric Chart Showing Performance of Heat Recovery Economizer in Cold Climate Effectiveness of air-to-air heat exchanger is 75% at full VAV flow (summer design) and 87% at minimum 25% VAV supply fan turndown (winter design). Building return air assumed to be 70°F. Outdoor air humidification for all hours per year in Climate Zone 2 shown on vertical axis. Supply fan energy savings of 75 to 80% would accrue during all Climate Zone 2 hours of operation (see [Table 1](#)).

Since all buildings have a different capacitance for moisture storage (Lstiburek 2017), a morning prehumidification strategy should be included as well as a morning preheat prior to occupancy after weekend or holiday shutdown for buildings with less than a 24/7/365 duty cycle. In [Figure 3](#), dampers A, B, and C are closed, the heat wheel and exhaust fans are off, the supply fan is on, and recirculation damper D is open. The preheat coil and the AC/H recirculation water pump are active. When building return air exceeds 45°F dp (adjustable), the AC/H pump is shut off. When building return air is above 70°F (adjustable), the HW coil valve is closed.

During the prehumidification cycle, water vapor molecules off the AC/H are stored inside the building, in the vapor state on hygroscopic surfaces. These water molecules may then be released to the indoor environment to maintain a more stable indoor humidity during occupancy.

Wet-Bulb Economizer for Indoor Humidity Control Using Equivalent Outdoor Air

[Figure 5A](#) shows a flow schematic of a wet-bulb economizer, without heat recovery that has a 50% supply fan turn down during cold ambient temperatures in winter. Using a 93% saturation efficiency adiabatic cooler/humidifier (AC/H) at the winter 50% flow rate and with ASHRAE *Standard* 62.1-2020 calling for a minimum outdoor air requirement of 25% of the full flow rate, the psychrometric chart ([Figure 5B](#)) shows that a 50/50 mixture of 37°F outdoor air with 70°F return air will result in a 53.5°F db and 45°F wb mixed condition and yield a 45°F db/44.5°F dp supply air to the building. Selecting 45°F db in lieu of the more conventional 55°F db VAV delivery temperature will result in a 75% fan energy reduction for all the winter hours the system is able to develop a 45°F db and dp temperature without preheat at the central station air-handling unit (see Climate Zone 2, [Table 1](#)).

The annual bin weather data for Chicago, Illinois, as a typical cold northern U.S. city, shows that there are approximately 3047 hours per year (35% of the annual hours) for a building with a 24/7/365 duty cycle when free humidification may be furnished without preheating at the air handling unit. The boiler and chiller are off during these ambient conditions. Climate change is working to move many more extreme cold ambient conditions above the 37°F threshold where the AC/H can keep the boiler off.

Risbeck et al. (2022) discuss the use of equivalent outdoor air (EOA) and MERV 13 filters (or higher efficiency filters) to reduce energy costs by using 50% less outdoor air than the building minimum outdoor air as calculated by ASHRAE

Standard 62.1-2020. Since MERV 13 filters will effectively remove all viruses from the building return air, the recirculated room air is considered as pathogen free after filtration as outdoor air. The author also suggests allowing the VAV supply air set point to be increased to 62°F db for the air-side economizer. In Chicago, cutting the minimum outdoor air by 50% and increasing the supply air set point to 62°F db, wb, and dp supply air for buildings with a 24/7/365 duty cycle would increase the hours per year of low-cost humidification to 66% of the annual ambient conditions.




Figure 5. (A) Airflow Schematic of AHU with Wet-Bulb Mixing Box (MB) Economizer Using High-Saturation-Efficiency Rigid-Media AC/H for Low-Cost Indoor Room rh Control and (B) Wet-Bulb Economizer Process to Control Supply Air Dew Point between 45 and 55°F dp VAV supply fan is controlled to meet room cooling load requirements with delivery temperatures from 45 to 55°F {7.2 to 12.8°C} dp, db, and wb at saturation curve during cold ambient conditions. Indoor relative humidity is maintained between 40 and 60%. If MERV 13 filtration is provided in final filter (FF) area of part (A), minimum code outdoor airflow can be reduced by 50% and replaced with room return air, which is considered EOA with the removal of airborne pathogens.

The AC/H component (Figure 2) in an air handling unit, such as the one shown in Figure 3, adds about \$1.50 to \$1.75 per supply air cfm to the unit first cost. This added first cost would have a rapid payback when the payroll savings affected by an increase in productivity and reduced absenteeism are evaluated (Taylor 2021). The heat wheel has a first cost of approximately \$2.00 to \$2.50 per cfm installed in the air-handling unit shown in Figure 3. Using EOA and MERV 13 filters would allow the owner to avoid the higher first cost and maintenance costs of a heat wheel.

Recirculated Water. Except for the small amount of energy added by shaft work from the recirculating pump and the small amount of heat leakage through the unit enclosure, evaporative humidification is strictly adiabatic. As the recirculated liquid evaporates, its temperature approaches the thermodynamic wet-bulb temperature of the entering air.

The air stream cannot be brought to complete saturation, but its state point changes adiabatically along a line of constant wet-bulb temperature. Typical saturation or humidifying effectiveness of various air washer spray arrangements is between 50 and 98%. The degree of saturation depends on the extent of contact between air and water. Other conditions being equal, low-velocity airflow is conducive to higher humidifying effectiveness.

Preheated Air. Preheating air increases both the dry- and wet-bulb temperatures and lowers the relative humidity; it does not, however, alter the humidity ratio (i.e., mass ratio of water vapor to dry air) or dew-point temperature of the

air. At a higher wet-bulb temperature but with the same humidity ratio, more water can be absorbed per unit mass of dry air in passing through the direct evaporative humidifier. Analysis of the process that occurs in the direct evaporative humidifier is the same as that for recirculated water. The desired conditions are achieved by heating to the desired wet-bulb temperature and evaporatively cooling at constant wet-bulb temperature to the desired dry-bulb temperature and relative humidity. Relative humidity of the leaving air may be controlled by (1) bypassing air around the direct evaporative humidifier or (2) reducing the number of operating spray nozzles or the area of media wetted.

Heated Recirculated Water. Heating humidifier water increases direct evaporative humidifier effectiveness. When heat is added to the recirculated water, mixing in the direct evaporative humidifier may still be modeled adiabatically. The state point of the mixture should move toward the specific enthalpy of the heated water. By raising the water temperature, the air temperature (both dry- and wet-bulb) may be raised above the dry-bulb temperature of entering air. The relative humidity of leaving air may be controlled by methods similar to those used with preheated air.

Dehumidification and Cooling

Direct evaporative coolers may also be used to cool and dehumidify air. If the entering water temperature is cooled below the entering wet-bulb temperature, both the dry- and wet-bulb temperatures of the leaving air are lowered. Dehumidification results if the leaving water temperature is maintained below the entering air dew point. Moreover, the final water temperature is determined by the sensible and latent heat absorbed from the air and the amount of circulated water, and it is 1 to 2°F below the final required dew-point temperature.

The air leaving a direct evaporative cooler being used as a dehumidifier is substantially saturated. Usually, the spread between dry- and wet-bulb temperatures is less than 1°F. The temperature difference between leaving air and leaving water depends on the difference between entering dry- and wet-bulb temperatures and on certain design features, such as the cross-sectional area and depth of the media or spray chamber, quantity and velocity of air, quantity of water, and the water distribution.

Air Cleaning

Direct evaporative coolers of all types perform some air cleaning. See the section on Air Cleaning and Sound Attenuation for detailed information.

2. INDIRECT EVAPORATIVE COOLING SYSTEMS FOR COMFORT COOLING

Several types of indirect evaporative cooling systems are used for commercial, institutional, and industrial cooling applications. [Figures 6](#) to [10](#) show schematics of the five most common dry evaporative cooling systems.




Figure 6. Heat Pipe Air-to-Air Heat Exchanger with Sump Base




Figure 7. Cross-Flow Plate Air-to-Air Indirect Evaporative Cooling Heat Exchanger




Figure 8. Rotary Heat Exchanger with Direct Evaporative Cooling

Indirect evaporative cooling efficiency is measured by the approach of the outdoor air dry-bulb condition to either the room return air or scavenger outdoor air wet-bulb condition on the wet side of the air-to-air heat exchanger. The **wet-bulb depression efficiency (WBDE)** is expressed as follows:

$$\text{WBDE} = \frac{t_1 - t_2}{t_1 - t_3} \times 100$$

where

- t_1 = supply air inlet dry-bulb temperature, °F
- t_2 = supply air outlet dry-bulb temperature, °F
- t_3 = wet-side air inlet wet-bulb temperature, °F




Figure 9. Coil Energy Recovery Loop with Direct Evaporative Cooling

The heat pipe air-to-air heat exchanger in [Figure 5](#) uses a direct water spray from a recirculation sump on the wet side of the heat pipe tubes (Scofield and Taylor 1986). When either room return or scavenger outdoor air passes over the wet surface, outdoor air entering the building is dry-cooled and produces an approach to the wet-side wet-bulb temperature in the range of 60 to 80% WBDE for equal mass flow rates on both sides of the heat exchanger. The WBDE is a function of heat exchanger surface area, face velocity, and completeness of wetting achieved for the wet-side heat exchanger surface. Face velocities on the wet side are usually selected in the range of 400 to 450 fpm.

[Figure 7](#) shows an indirect evaporative cooling (IEC) heat exchanger. This cross-flow, polymer tube air-to-air heat exchanger uses a sump pump to circulate water to wet the outside of the horizontal heat exchanger tubes. A secondary air fan draws either building return or outdoor air vertically upward over the outside of the wetted tubes, causing evaporative cooling to occur. Outdoor air entering the building passes horizontally through the inside of the polymer tube bundle and is sensibly (dry) cooled. Latent and sensible cooling may occur in the outdoor makeup air stream if the secondary air's wet-bulb temperature is lower than the outdoor air's dew-point temperature.

The heat wheel ([Figure 8](#)) and the run-around coil ([Figure 9](#)) both use a direct evaporative cooling component on the cold side to enhance the dry-cooling effect on the makeup air side. The heat wheel (sensible transfer), when sized for 500 fpm face velocity with equal mass flows on both sides, has a WBDE around 60 to 70%. The run-around coil system at the same conditions produces a WBDE of 35 to 50%. The adiabatic cooling component is usually selected for an effectiveness of 85 to 95%. Water coil freeze protection is required in cold climates for the run-around coil loop.

Air-to-air heat exchangers that are directly wetted produce a closer approach to the cold-side wet-bulb temperature, all things being equal. First cost, physical size, and parasitic losses are also reduced by direct wetting of the heat exchanger. In applications having extremely hard makeup water conditions, using a direct evaporative cooling device in lieu of directly wetting the air-to-air heat exchanger may reduce maintenance costs and extend the useful life of the system.

All of the air-to-air heat exchangers shown in [Figures 6](#) to [9](#) produce beneficial winter heat recovery when using building return air with the sprays or adiabatic cooling component turned off.

[Figure 10](#) shows a cooling-tower-to-coil indirect evaporative cooling system with WBDE in the range of 50 to 75% (Colvin 1995). This system is sometimes called a water-side economizer. The cooling tower is selected for a close approach to the ambient wet-bulb temperature, with sump water from the tower then pumped to precooling coils in an air-handling unit. A plate-and-frame heat exchanger or water filtration to remove solids from sump water is needed, and water coils may need to be cleanable. Freeze protection of the water coil loop is required in cold climates. No winter heat recovery is available with this design.




Figure 10. Cooling-Tower-to-Coil Indirect Evaporative Cooling

Table 2 Indirect Evaporative Cooling Systems Comparison

System Type ^a	WBDE, ^b %	Heat Recovery Efficiency, %	Wet-Side Air ΔP , in. of water	Dry-Side Air ΔP , in. of water	Pump hp per 10,000 cfm	Parasitic Loss Range, ^e kW/ton of Cooling	Equipment Cost Range, ^f \$/Supply cfm	Notes
Cooling tower to coil	40 to 60	NA	NA	0.4 to 0.7	Varies	Varies	0.50 to 1.00	Best for serving multiple AHUs from a single cooling tower. No winter heat recovery.
Cross-flow plate	60 to 85	40 to 50	0.7 to 1.0	0.4 to 0.7	0.1 to 0.2	0.12 to 0.20	1.20 to 1.70	Most cost-effective for lower airflows. Some cross contamination possible. Low winter heat recovery.
Heat pipe ^c	65 to 75	50 to 60	0.7 to 1.0	0.5 to 0.7	0.2 to 0.4	0.15 to 0.25	1.50 to 2.50	Most cost-effective for large airflows. Some cross contamination possible. Medium winter heat recovery.
Heat wheel ^d	60 to 70	70 to 80	0.6 to 0.9	0.4 to 0.65	0.1 to 0.2	0.2 to 0.3	1.50 to 2.50	Best for high airflows. Some cross contamination. Highest winter heat recovery rates.
Runaround coil ^d	35 to 50	40 to 60	0.6 to 0.8	0.4 to 0.6	Varies	> 0.35	1.00 to 2.00	Best for applications where supply and return air ducts are separated. Lowest summer WBDE.

WBDE = wet-bulb depression efficiency

Notes:

^a All air-to-air heat exchangers have equal mass flow on supply and exhaust sides.

^b Plate and heat pipe are direct spray on exhaust side. Heat wheel and runaround coil systems use 90% WBDE direct evaporative cooling media on exhaust air side.

^c Assumes six-row heat pipe, 11 fpi, with 500 fpm face velocity on both sides.

^d Assumes 500 fpm face velocity. Parasitic loss includes wheel rotational power.

^e Includes air-side static pressure and pumping penalty.

^f Excludes cooling tower cost and assumes less than 200 ft piping between components.

[Table 2](#) gives the designer some performance predictions and application limits that may be helpful in determining the indirect evaporative cooling system that best solves the design problem at hand. If winter heat recovery is a priority, the heat wheel system may provide the quickest payback. Runaround coil systems are applied where supply air and exhaust air ducts are remote from each other. The heat pipe adapts well to high-volume air-handling systems where cooling energy reduction is the priority. The plate heat exchanger fits smaller-volume systems with high cooling requirements but with lower winter heat recovery potential. Des Champs and Dunnivant (2014) give additional information on air-side economizers using direct and indirect evaporative cooling in data centers.

Indirect Evaporative Cooling Controls

Where the heat exchanger is directly wetted, a water hardness monitor for the recirculation water sump is recommended. Water hardness should be kept within 200 to 500 parts per million (ppm) to minimize plating out of dissolved solids from the sump water. To maintain its set point, the hardness monitor may initiate a sump dump cycle when it detects increased water hardness. In addition, the sump should have provisions for a fixed bleed so that extra makeup water is continuously introduced to dilute dissolved solids left behind when water evaporates from the wetted heat exchanger surface. Sumps should always be drained at the end of a duty cycle and refilled the next day when the system is turned on. For rooftop applications, sumps should be drained for freeze protection during low ambient temperatures.

Air-side control for a cooling system with a 55°F supply air set point may be set up as follows. The heat exchanger's wet-side sprays or indirect evaporative cooling component should be activated whenever ambient dry-bulb temperatures exceed 65°F, if room return air is used on the wet side of the air-to-air heat exchanger. Air-conditioned buildings have a stable return air wet-bulb condition in the range of 60 to 65°F. Outdoor air may be usefully precooled when ambient dry-bulb temperatures exceed the return air wet-bulb condition.

Where outdoor air is used on the cold-air side of the heat exchanger, cooling may begin at ambient temperatures above 55°F, because the wet-bulb condition of outdoor air is always lower than its dry-bulb condition.

Parasitic losses generated by the heat exchanger static pressure penalty to supply and return air fans and by the water pump need to be evaluated. These losses may be mitigated by opening bypass dampers around the heat exchanger for pressure relief and shutting off the pump in the ambient temperature range of 55 to 65°F db. Where outdoor air is used on the wet side (scavenger air) of an air-to-air heat exchanger, this temperature range may be reduced somewhat. Comparing the energy penalty to the precooling energy avoided determines the optimum range of ambient conditions for this control strategy.

For variable-air-volume (VAV) supply and return fan systems, the static penalty reduces by the square of the airflow reduction from full design flow at summer peak design condition. As airflow rates decrease across an air-to-air heat exchanger, the WBDE increases, thereby providing better precooling. Where scavenger outdoor air is used for indirect evaporative cooling, the wet-side airflow rate is usually constant volume.

Winter heat recovery may be initiated at ambient temperatures below the 55°F supply air set point. Where building return air is used with an air-to-air heat exchanger, the 70 to 75°F return air condition is used to preheat makeup air for the building. For a VAV supply air system, [Figure 11](#) shows the increased ventilation potential of a heat pipe air-to-air heat exchanger that uses face and bypass dampers on the supply air side to mix unheated outdoor air with preheated outdoor air to maintain the 55°F building supply air set point (Scofield and Bergman 1997). The heat pipe leaving air temperature may also be controlled with a tilt control (see [Chapter 26 of the 2020 ASHRAE Handbook—HVAC Systems and Equipment](#)). With a heat pipe economizer, a minimum outdoor air ventilation rate of 20% would not be breached until ambient temperatures dropped below –15°F.




Figure 11. Increased Winter Ventilation

Runaround coils control leaving supply air temperature with a three-way valve (see [Figure 9](#)). Because of their higher parasitic losses, these systems may require a wider range of ambient conditions where pressure-relief bypass dampers are open and the pump system shut down. Some projects limit activation of these recovery systems to ambient temperatures above 85°F or below 40°F.

Indirect/Direct Evaporative Cooling with VAV Delivery

Coupling indirect and direct evaporative cooling to a variable-air-volume (VAV) delivery system in arid climates can effectively eliminate requirements for mechanical refrigeration in many applications. Many cities in the western United States have summer design conditions suitable to deliver 55°F or lower supply air to a building using a 70% WBDE indirect and a 90% effective direct evaporative cooling system.

[Figure 12](#) shows plan and elevation views of an air-handling unit using a sprayed heat pipe air-to-air heat exchanger and a wetted-media direct evaporative cooling section augmented by a final-stage chilled-water cooling coil (Scofield and Bergman 1997). The 70% indirect WBDE is achieved with a direct-sprayed heat pipe using a sump and a recirculation water system on the building return air side of the heat exchanger. The 90% effective direct evaporative cooling medium is split into two sections for two-stage cooling capacity control of the 55°F leaving air temperature. The direct evaporative cooling system also uses a sump and water recirculation. Supply-side heat pipe face and bypass dampers control the final supply air temperature (55°F) in both summer (when indirect sprays are on) and winter, to control the heat pipe's heat recovery capacity. Heat pipe dampers on both sides of the heat exchanger are powered to full open to mitigate system parasitic losses during ambient temperature conditions when the value of energy recovered is exceeded by the fan energy penalty. The recirculation damper is used for morning warm-up of the building and for blending building return air with preheated outdoor air during extreme cold ambient conditions (see [Figure 11](#)).




Figure 12. Heat Pipe Air-Handling Unit

Table 3 Sacramento, California, Cooling Load Comparison

Outdoor Air db/wb, °F	VAV Supply, cfm	Hours Per Year ^d	100% Outdoor Air Indirect-Direct Evaporative Cooling				25% Outdoor Air Economizer			
			Indirect LAT db/wb, °F	Direct LAT db/wb, °F	Refrigeration, ^a tons	Refrigeration, ^b ton · h	Mixed Air db/wb, °F	Refrigeration, ^a tons	Refrigeration, ^b ton · h	
107/70	10,000	7	76.9/60	61.7/60	14.2	99.4	83/65.5	29.2	204.4	
102/70	9,688	59	75.4/61.3	62.7/61.3	17.4	1026.6	81.8/65.5	28.3	1669.7	
97/68	9,375	144	73.9/60.1	61.5/60.1	14	2016	80.5/65.0	25.9	3729.6	
92/66	9,062	242	72.4/59.1	60.4/59.1	11.5	2783	79.2/64.5	23.7	5735.4	
87/65	8,750	301	70.9/59.3	60.5/59.3	10.5	3160.5	78/64.3	22.3	6712.3	
82/63	8,438	397	69.4/58.7	59.8/58.7	9.5	3771.5	76.8/63.9	20.3	8059.1	
77/61	8,125	497	67.9/57.7	58.7/57.7	6.7	3329.9	77.5/63.3	18.3	9095.1	
72/59	7,812	641	66.4/56.8	57.8/56.8	5.3	3397.3	72/59 ^b	12.9	8268.9	
67/57	7,500	821	64.9/56.0	56.9/56.0	3.9	3201.9	67/57 ^b	9	7389	
62/54	7,188	1086	62/54	54.8/54	0	0	62/54 ^b	4.3	4669.8 ^c	
57/52	6,875	1290	57/52	52.5/52	0	0	57/52 ^b	1	1290 ^c	

Total ton · h = 22,786.1

Total ton · h = 56,823.3

LAT = leaving-air temperature


Notes:^a Amount of cooling required to reach 55°F db supply air requirements.^b Ambient conditions when dampers for air-side economizer introduce 100% outdoor air in arid climates.^c Ambient conditions when 90% saturation efficiency direct evaporative cooler may be used to eliminate refrigeration cooling. Heat pipe bypass dampers should be open to minimize parasitic losses. Indirect water sprays should be off.^d Bin hours at each condition based on 24 h/day, 365 day/year duty cycle.**Table 4 Sacramento, California, Heat Recovery and Humidification**

Outdoor Air db/wb, °F	VAV Supply, ^a cfm	Hours Per Year ^b	Heat Recovery Leaving Air db/wb, °F	Direct Evaporative Humidifier Leaving Air db/wb, ^c °F	Energy Savings, ^d Btu/h	Resultant Room rh
52/48	6562	1199	62.8/52.7	55/52.7	73,822	54%
47/44	6250	924	60.8/50.5	55/50.5	90,000	47%
42/40	5938	660	58.8/48.1	55/48.1	98,868	38%
37/36	5625	333	56.8/46.0	55/46.0	120,285	32%
32/31	5312	116	54.8/43.2	OFF	130,803	25% ^e
27/26	5000	30	52.8/41.0	OFF	250,776	21% ^e

Source: Scofield and Bergman (1997).^a VAV turndown airflow is assumed linear from summer design (10,000 cfm) to winter design (5000 cfm).^b Bin hours at each condition based on 24 h/day, 365 days/year duty cycle.^c Heat pipe overheats outdoor air to allow direct evaporative humidifier to add moisture.^d Recirculated building heat used for preheating 100% outdoor air and increasing humidity levels.^e Additional heat is required or recirculation damper must open during these bin conditions, to maintain both acceptable 30% indoor relative humidity and reach the 55°F supply air set point.

[Table 3](#) uses ASHRAE bin weather data for the semi-arid climate of Sacramento, California, to illustrate potential cooling energy savings for a 10,000 cfm VAV design that turns down to 5000 cfm at winter design (Scofield and Bergman 1997). Compared to a conventional-refrigeration cooling VAV design with a 25% minimum outdoor air economizer, the two-stage evaporative cooling system reduces peak cooling load by 49% while introducing 100% outdoor air. For a building duty cycle of 8760 h per year, the ton-hour savings is 34,037, or a 60% reduction compared to the conventional air-side economizer system with mechanical cooling only. For ambient bin conditions of 62°F db/54°F wb to 57°F db/52°F wb, there are 2376 cooling hours per year (27% of the annual cooling hours) where a 90% wet-bulb depression efficiency (WBDE) direct evaporative cooling system may be used for the 55°F supply air requirement without refrigeration.

[Figure 13](#) uses typical meteorological year (TMY) data for 14 cities in the western United States to illustrate the evaporative cooling annual refrigeration avoidance per 10,000 cfm of VAV supply air, compared to a 25% minimum outdoor air economizer (Scofield and Bergman 1997). For thermal energy storage (TES) applications, the two-stage evaporative cooling design may significantly reduce chiller plant storage capacity and refrigeration equipment first cost.



Note: Fourteen Western cities where indirect/direct evaporative cooling systems, using heat pipe (wet) indirect evaporative effectiveness of 70% and direct evaporative cooler saturation efficiency of 90%, can be used to introduce 100% outdoor air, with substantial reductions in ton-hour cooling requirements compared to conventional 25% outdoor air economizer damper design. Ton-hour totals for each system based on 24 h/day, 365 day/year duty cycle and 10,000 cfm VAV supply air. NREL hour-by-hour TMY data used to develop ton-hours listed. Fan heat not included.

Figure 13. Refrigeration Reduction with Two-Stage Evaporative Cooling Design

Benefits of this design in dry climates include the following:

- Indoor air quality is improved by using all-outdoor air during cooling, and increased ventilation in winter through the heat pipe economizer (see [Figure 11](#)).
- Energy demand is in the range of 0.15 to 0.25 kW per ton of cooling, versus air-cooled refrigeration at 1.2 to 1.3 kW per ton.
- Peak building electrical cooling and gas heating demand requirements are reduced, especially for applications that require higher amounts of outdoor air.
- Because VAV pinchdown terminals may reduce their minimum airflow settings and comply with ASHRAE *Standard* 62.1, supply and return fan energy savings are possible in cooler weather when using an all-outdoor-air design.
- VAV turndown of fans during cooler ambient conditions decreases fan parasitic energy losses because of the evaporative cooling system components.
- VAV turndown increases the WBDE of both the air-to-air heat exchanger and direct evaporative cooling system.
- In semi-arid climates where a chilled-water final cooling stage is required, two-stage evaporative cooling allows central chilled-water plants to be turned off earlier in the fall and reactivated later in the spring. This results in significant maintenance and cooling energy cost savings.
- In cooler weather, resetting supply air down to 50°F and using only the direct evaporative cooler extends free cooling hours and reduces fan energy.
- When using building return air, winter heat recovery provides increased outdoor air quantities during the period when fan turndown can result in loss of proper ventilation rates for VAV systems (see [Figure 11](#)).
- During mild winter daytime ambient conditions, the 4 in. deep wetted media section may be used for beneficial building humidification (see [Table 4](#)).

Beneficial Humidification

Areas with mild winter climates (e.g., the western U.S. coast) may use the heat available in building return air, through the air-to-air heat exchanger, to overheat supply air and add building humidification during the driest season of the year. The 4 in. section of direct evaporative cooling media (see [Figure 11](#)) is used in cool ambient conditions as a humidifier. [Table 4](#) (Scofield and Bergman 1997) extends the [Table 3](#) bin weather data for the Sacramento, California, site into winter ambient conditions. The table shows that 100% outdoor air may be introduced and humidity controlled between 54 and 32% for ambient conditions down to 37°F with a 60% heat pipe recovery effectiveness. There are only 146 bin hours below the 37°F ambient threshold during which the building recirculation air damper (see [Figure 11](#)) would have to open or additional heat be added with the hot-water coil to maintain the 55°F air delivery set point. The average winter temperature in Sacramento is 52.7°F.

Indirect Evaporative Cooling With Heat Recovery

In indirect evaporative cooling, outdoor supply air passes through an air-to-air heat exchanger and is cooled by evaporatively cooled air exhausted from the building or application. The two airstreams never mix or come into contact, so no moisture is added to the supply airstream. Cooling the building's exhaust air results in a larger overall temperature difference across the heat exchanger and a greater cooling of the supply air. Indirect evaporative cooling requires only fan and water pumping power, so the coefficient of performance tends to be high. The principle of indirect evaporative cooling is effective in most air-conditioned buildings, because evaporative cooling is applied to exhaust air rather than to outdoor air.

Indirect evaporative cooling has been applied in a number of heat recovery applications (Mathur et al. 1993), such as plate heat exchangers (Scofield and DesChamps 1984; Wu and Yellot 1987), heat pipe exchangers (Mathur 1998; Scofield 1986), rotary regenerative heat exchangers, and two-phase thermosiphon loop heat exchangers (Mathur 1990). In residential air conditioning, the outdoor condensing unit can be evaporatively cooled to enhance performance (Mathur 1997; Mathur and Goswami 1995; Mathur et al. 1993). Indirect evaporative cooling with heat recovery is covered in detail in [Chapter 26 of the 2020 ASHRAE Handbook—HVAC Systems and Equipment](#).

3. BOOSTER REFRIGERATION

Staged evaporative coolers can completely cool office buildings, schools, gymnasiums, sports facilities, department stores, restaurants, factory space, and other buildings. These coolers can control room dry-bulb temperature and relative humidity, even though one stage is a direct evaporative cooling stage. In many cases, booster refrigeration is not required. Supple (1982) showed that even in higher-humidity areas with a 1% mean wet-bulb design temperature of 75°F, 42% of the annual cooling load can be satisfied by two-stage evaporative cooling. Refrigerated cooling need supply only 58% of the load.

[Figure 14](#) shows indirect/direct two-stage performance for 16 cities in the United States. Performance is based on 60% WBDE of the indirect stage and 90% for the direct stage. Supply air temperatures (leaving the direct stage) at the 0.4% design dry-bulb mean coincident wet-bulb condition range from 56.1 to 72.3°F. Energy use ranges from 16.4 to 51.8%, compared to conventional refrigerated equipment.

Booster mechanical refrigeration provides indoor design comfort conditions regardless of the outdoor wet-bulb temperature without having to size the mechanical refrigeration equipment for the total cooling load. If the indoor humidity level becomes uncomfortable, the quantity of moisture introduced into the airstream must be limited to control room humidity. Where the upper relative humidity design level is critical, a life-cycle cost analysis favors a design with an indirect cooling stage and a mechanical refrigeration stage.

[Figure 15](#) shows an air-handling unit design that uses building return air instead of outdoor air to develop the indirect (dry) evaporative cooling effect with a direct-sprayed, heat pipe, air-to-air, heat exchanger (Felver et al. 2001). The humid, cool air off the heat pipe is then used to reject the heat of refrigeration at a condenser coil downstream of the exhaust fan. The direct expansion (DX) cooling coil, the last component in the supply air, develops the final building supply air temperature when the two-stage evaporative cooling components cannot meet the design cooling requirements. [Figure 16](#) shows the process points for both supply and exhaust airstreams, using the Stockton, California, ASHRAE 0.4% summer dry-bulb design ambient condition. Several benefits accrue from this evaporative cooling design:

- Building return air has a more predictable and stable wet-bulb condition (60 to 65°F) than ambient air for use in generating the first stage of indirect (dry) evaporative cooling. Daytime absorption of moisture inside most buildings further enhances the first-stage cooling effect.
- Locating a DX condenser coil in sprayed exhaust off the heat pipe results in a more efficient rejection of refrigeration heat than a condenser coil located outdoors in the ambient air.
- Lower refrigeration condensing temperatures increase compressor capacity and compressor life, and reduce energy consumption.

- Central chilled-water plant or remote chiller installation and piping costs are eliminated.
- Evaporative cooling components provide back-up cooling capability in case of compressor failure. [Figure 16](#) shows equilibrium conditions in the occupied area with indirect/direct evaporative cooling only at the design dry-bulb ambient condition.
- Peak refrigeration demand can be reduced 14 to 40% in California’s semi-arid climate (Scofield 1994).
- Blow-through supply fan and draw-through exhaust fans provide
 - Reduced supply fan heat addition for DX cooling system
 - Reduced risk of cross contamination of supply air with exhaust air for hospital or laboratory applications
 - Reduced fan noise breakout into building duct system




Figure 14. Indirect/Direct Two-Stage System Performance

There are several design considerations for the successful integration of DX refrigeration with two-stage evaporative cooling air-handling units, as shown in [Figure 15](#).

For both constant-volume (CV) and variable-air-volume (VAV) units, the return air must closely match the supply airflow to ensure adequate heat rejection at the condenser coil. Buildings with large fixed-exhaust systems may not provide sufficient building return airflow for absorption of refrigeration heat at acceptable refrigerant condensing temperatures.

Secondary face-and-bypass dampers are required around the condenser coil for control of the refrigerant condensing pressure and temperature.

Note that peak refrigeration requirements always occur during the highest ambient humidity (dew-point design) conditions. In semi-arid climates, this design condition occurs during reduced summer ambient dry-bulb temperatures (Ecodyne Corp. 1980). Review of site ASHRAE dew-point design conditions ([Chapter 14 of the 2021 ASHRAE Handbook—Fundamentals](#)) is required to determine the peak refrigeration cooling capacity needed to maintain the specified supply air temperature set point to the building.

4. RESIDENTIAL OR COMMERCIAL COOLING

In dry climates, evaporative cooling is effective at lower air velocities than those required in humid climates. Packaged direct evaporative coolers are used for residential and commercial application. Cooler capacity may be determined from standard heat gain calculations (see [Chapters 17](#) and [18 of the 2021 ASHRAE Handbook—Fundamentals](#)).

Detailed calculation of heat load, however, is usually not economically justified. Instead, one of several estimates gives satisfactory results. In one method, the difference between dry-bulb design temperature and coincident wet-bulb

temperature divided by 10 is equal to the number of minutes needed for each air change. This or any other arbitrary method for equating cooling capacity with airflow depends on a direct evaporative cooler effectiveness of 70 to 80%. Obviously, the method must be modified for unusual conditions such as large unshaded glass areas, uninsulated roof exposure, or high internal heat gain. Also, such empirical methods make no attempt to predict air temperature at specific points; they merely establish an air quantity for use in sizing equipment.




Figure 15. Two-Stage Evaporative Cooling with Third-Stage Integral DX Cooling Design




Figure 16. Psychrometrics of 100% OA, Two-Stage Evaporative Cooling Design (20,000 cfm Supply, 18,000 cfm Return) Compared with 10% OA Conventional System Operating at Stockton, California, ASHRAE 0.4% db Design Condition

Example 1. An indirect evaporative cooler is to be installed in a 50 by 80 ft one-story office building with a 10 ft ceiling and a flat roof. Outdoor design conditions are assumed to be 95°F db and 65°F wb. The following heat gains are to be used in the design:

	Heat Gains, Btu/h
All walls, doors, and roof	78,500
Glass area	5,960
Occupants (sensible load)	17,000
Lighting	62,700
Total sensible heat load	164,160
Total latent load (occupants)	21,2516
Total heat load	185,410

Find the required air quantity, the temperature and humidity ratio of the air leaving the cooler (entering the office), and the temperature and humidity ratio of the air leaving the office.

Solution: A temperature rise of 10°F in the cooling air is assumed. The airflow rate that must be supplied by the indirect evaporative cooler may be found from the following equation:

$$Q_{ra} = \frac{q_s}{60\rho c_p(t_1 - t_s)} = \frac{164,160}{60 \times 0.018 \times 10} = 15,200 \text{ cfm} \quad (1)$$

where

- Q_{ra} = required airflow, cfm
- q_s = instantaneous sensible heat load, Btu/h
- t_1 = indoor air dry-bulb temperature, °F
- t_s = room supply air dry-bulb temperature, °F
- ρc_p = density times specific heat of air $\approx 0.018 \text{ Btu/ft}^3 \cdot \text{°F}$

This air volume represents a 2.6 min ($50 \times 80 \times 10/15,200$) air change for a building of this size. The indirect evaporative air cooler is assumed to have a saturation effectiveness of 80%. This is the ratio of the reduction of the dry-bulb temperature to the wet-bulb depression of the entering air. The dry-bulb temperature of the air leaving the indirect evaporative cooler is found from the following equation:

$$t_2 = t_1 - \frac{e_h}{100}(t_1 - t') = 95 - \frac{80}{100}(95 - 65) = 71^\circ\text{F} \quad (2)$$

where

- t_2 = dry-bulb temperature of leaving air, °F
- t_1 = dry-bulb temperature of entering air, °F
- e_h = humidifying or saturating effectiveness, %
- t' = thermodynamic wet-bulb temperature of entering air, °F

From the psychrometric chart, the humidity ratio W_2 of the cooler discharge air is 0.01185 lb/lb_{da}. The humidity ratio W_3 of the air leaving the space being cooled is found from the following equation:

$$W_3 = \frac{q_e}{4840Q_{ra}} + W_2 \quad (3)$$

$$W_3 = \frac{21,250}{4840 \times 15,200} + 0.01185 = 0.01214 \text{ lb/lb (dry air)}$$

where q_e = latent heat load in Btu/h.

The remaining values of wet-bulb temperature and relative humidity for the problem may be found from the psychrometric chart. [Figure 17](#) shows the various relationships of outdoor air, supply air to the space, and discharge air.

The wet-bulb depression (WBD) method to estimate airflow gives the following result:

$$\text{WBD}/10 = (95 - 65)/10 = 3.0 \text{ min per air change}$$

$$Q_{ra} = \frac{\text{Volume}}{\text{Air change rate}} = \frac{80 \times 50 \times 10}{3.0} = 13,300 \text{ cfm}$$

Although not exactly alike, these two air volume calculations are close enough to select cooler equipment of the same size.

5. EXHAUST REQUIRED

If air is not exhausted freely, the increased static pressure will reduce airflow through the evaporative cooler. The result is a marked increase in the moisture and heat absorbed per unit mass of air leaving the evaporative cooler. Reduced airflow also reduces the air velocity in the room. The combination of these effects reduces the comfort level. Properly designed systems should have a minimum of 2 ft² of exhaust area for every 1000 cfm. If the exhaust area is not sufficient, a powered exhaust should be used. The amount of power depends on the total airflow and the amount of free or gravity exhaust. Some applications require that the powered exhaust capacity equal the cooler output.




Figure 17. Psychrometric Diagram for Example 1

6. TWO-STAGE COOLING

Two-stage coolers for commercial applications can extend the range of atmospheric conditions under which comfort requirements can be met, as well as reduce the energy cost. For the same design conditions, two-stage cooling provides lower cool-air temperatures, which reduces required airflow.

7. INDUSTRIAL APPLICATIONS

In factories with large internal heat loads, it is difficult to approach outdoor conditions during the summer simply by ventilating without using extremely large quantities of outdoor air. Both direct and indirect evaporative cooling may be used to reduce heat stress with less outdoor air. Evaporative cooling normally results in lower effective temperatures than ventilation alone, regardless of the ambient relative humidity.

Effective Temperature. Comfort cooling in air-conditioned spaces is usually based on providing space temperature and relative humidity conditions for human comfort without a draft. The effective temperature relates the cooling effects of air motion and relative humidity to the effect of conditioned (cooled) air. [Figure 18](#) shows an effective temperature chart for air velocities from 20 to 700 fpm. Although the maximum velocity shown on the chart is 700 fpm, workers exposed to high-heat-producing operations may prefer air movement up to 4000 fpm to offset the radiant heat effect of equipment. Because the normal working range of the chart is approximately midway between the vertical dry- and wet-bulb scales, changes in either dry- or wet-bulb temperatures have similar effects on worker comfort. A reduction in either one decreases the effective temperature by about one-half of the reduction. Lines ED and CD on the chart show this.




Figure 18. Effective Temperature Chart

A condition of 95°F db and 75°F wb was chosen as the original state, because this condition is usually considered the summer design criterion in most areas. Reducing the temperature 15°F by evaporating water adiabatically provides an effective temperature reduction of 5.5°F for air moving at 20 fpm and a reduction of 9.5°F for air moving at 700 fpm, an improvement of 4°F.

The reduction in dry-bulb temperature through water evaporation increases the effectiveness of the cooling power of moving air in this example by 137%. On line ED, the effective temperature varies from 83°F at 20 fpm to 79.5°F at 700 fpm with unconditioned air, whereas line CD indicates an effective temperature of 77.5°F at 20 fpm and 70°F at 700 fpm with air cooled by a simple direct evaporative process. In the unconditioned case, increasing the air velocity from 20 to 700 fpm resulted in only a 3.5°F decrease in effective temperature. This contrasts with a 7.5°F decrease in effective temperature for the same range of air movement when the dry-bulb temperature was lowered by water

evaporation. This demonstrates that direct evaporative cooling can provide a more comfortable environment regardless of geographical location.

Two methods are demonstrated to illustrate the environmental improvement that may be achieved with evaporative coolers. In one method, shown in [Figure 19](#), temperature is plotted against time of day to show effective temperature depression over time. Curve A shows ambient maximum dry-bulb temperature recordings. Curve B shows the corresponding wet-bulb temperatures. Curve C depicts the effective temperature when unconditioned air is moved over a person at 300 fpm. Curve D shows air conditioned in an 80% effective direct evaporative cooler before being projected over the person at 300 fpm. Curve E shows the additional decrease in effective temperature with air velocities of 700 fpm. Although a maximum suggested effective temperature of 80°F is briefly exceeded with unconditioned air at 300 fpm (curve C), both the differential and total hours are substantially reduced from still-air conditions. Curves D and E illustrate that, despite the high wet-bulb temperatures, the in-plant environment can be continuously maintained below the suggested upper limit of 80°F effective temperature. This demonstration assumes that the combination of air velocity, duct length, and insulation between evaporative cooler and duct outlet is such that there is little heat transfer between air in ducts and warmer air under the roof.




Figure 19. Effective Temperature for Summer Day in Kansas City, Missouri (Worst-Case Basis)

[Figure 20](#) shows another method of demonstrating the effect of using direct evaporative coolers by plotting effective comfort zones using ambient wet- and dry-bulb temperatures on a psychrometric chart (Crow 1972). The dashed lines show the expected improvement when using an 80% effective direct evaporative cooler.

Area Cooling

Both direct and indirect evaporative cooling may be used for area or spot cooling of industrial buildings. Both can be controlled either automatically or manually. In addition, evaporative coolers can supply tempered air during fall, winter, and spring. Gravity or power ventilators exhaust the air. Area cooling works well in buildings where personnel move about and workers are not subjected to concentrated, radiant heat sources. Area cooling may be used in either high- or low-bay industrial buildings, but may provide significant advantages in high-bay construction where cooling loads associated with roofs, lighting, and heat from equipment may be effectively eliminated by taking advantage of stratification. When cooling an area, ductwork should be designed to distribute air to the lower 10 ft of the space to ensure that cooler air is supplied to the workers.

Cooling requirements change from day to day and season to season, so if discharge grilles are used, they should be adjustable to prevent drafts. The horizontal blades of an adjustable grille can be adjusted so that air is discharged above workers' heads rather than directly on them. In some cases, the air volume can be adjusted, either at each outlet or for the entire system, in which case the exhaust volume may need to be varied accordingly.

Spot Cooling

Spot cooling is a more efficient use of equipment when personnel work in one area. Cool air is brought to the spot at levels below 10 ft, and may even be delivered from floor outlets. Duct height may depend on the location of other equipment in the area. For best results, air velocity should be kept low. Controls may be automatic or manual, with the fan often operating throughout the year. Workers are especially appreciative of spot cooling in hot environments, such as in chemical plants and die casting shops, and near glass-forming machines, billet furnaces, and pig and ingot casting.

When spot-cooling a worker, the air volume depends on the throw of the air jet, worker activity, and amount of heat that must be overcome. Air volumes can vary from 200 to 5000 cfm per worker, with target velocities ranging between 200 to 4000 fpm. Outlets should be between 4 to 10 ft from workstations to avoid entrainment of warm air and to effectively blanket workers with cooler air. Workers should be able to control the direction of air discharge, because air motion that is appropriate for hot weather may be too great for cool weather or even cool mornings. Volume controls may be required to prevent overcooling the building and to minimize excessive grille blade adjustment.

Spot cooling is useful in rooms with elevated temperatures, regardless of climatic or geographical location. When the dry-bulb temperature of the air is below skin temperature, convection rather than evaporation cools workers. In these conditions, an 80°F air stream can provide comfort regardless of its relative humidity.

Cooling Large Motors

Electrical generators and motors are generally rated for a maximum ambient temperature of 104°F. When this temperature is exceeded, excessive temperatures develop in the electrical windings unless the load on the motor or generator is reduced. By providing evaporatively cooled air to the windings, this equipment may be safely operated without reducing the load. Likewise, transformer capacity can be increased using evaporative cooling.

Heat emitted by high-capacity electrical equipment may also be sufficient to raise the ambient condition to an uncomfortable level. With mill drive motors, an additional problem is often encountered with the commutator. If the air used to ventilate the motor is dry, the temperature rise through the motor results in a still lower relative humidity, at which the brush film can be destroyed, with unusual brush and commutator wear as well as the occurrence of dusting.

As a rule, a motor with a temperature rise of 25°F requires approximately 120 cfm of ventilating air per kilowatt-hour of loss. If inlet air to the motor is 95°F, air leaving the motor would be 120°F. This average motor temperature of over 107°F is 3°F higher than it should be for the normal 104°F ambient. The same quantity of 95°F db inlet air at 75°F wb can be cooled by a direct evaporative cooler with a 97% saturation effectiveness. The resulting 88°F average motor temperature eliminates the need for special high-temperature insulation and improves the motor's ability to absorb temporary overloads. By comparison, an air quantity of 185 cfm is required if supplied by a cooler with 80% saturation effectiveness.




Figure 20. Change in Human Comfort Zone as Air Movement Increases

[Figure 21](#) shows three basic arrangements for motor cooling. Air from the evaporative cooler may be directed on the motor windings, or into the room; the latter requires greater air volume to compensate for the building heat load. Direct evaporative cooler operation should be keyed to motor operation to ensure that (1) saturated or nearly saturated air is never introduced into a motor until it has had time to warm up, and (2) if more than one motor is served by a single system, air circulation through idle motors should be prevented.

Cooling Gas Turbine Engines and Generators

Combustion turbines used for electric power production are normally rated at 59°F. Their performance is greatly influenced by the compressor inlet air temperature because temperature affects air density and therefore mass flow. As ambient temperature increases, demand on electric utilities increases and combustion turbine capacity decreases. Capacity recovery due to inlet air cooling is approximately 0.4%/°F (cooling). Direct and indirect evaporative cooling is beneficial to gas turbine performance in almost all climates because when the air is the hottest, it generally has the lowest relative humidity. Expected increases in output using direct evaporative cooling range from 5.8% in Albany, New York, to 14% in Yuma, Arizona. In addition to increasing gas turbine output, direct evaporative cooling also improves heat rate and reduces NO_x emissions.




Figure 21. Arrangements for Cooling Large Motors

For an installation of this type, the following precautions must be taken: (1) mist eliminators must be provided to stop entrainment of free moisture droplets, (2) coolers must be turned off at a temperature below 45°F to prevent icing, and (3) water quality must be monitored closely (Stewart 1999).

Process Cooling

In the manufacture of textiles and tobacco and in processes such as spray coating, the required accurate relative humidity control can be provided by direct evaporative coolers. For example, textile manufacturing requires relatively high humidity and the machinery load is heavy, so a split system is customarily used to introduce free moisture directly into the room. The air handled is reduced to approximately 60% of that normally required by an all-outdoor-air, direct evaporative cooler.

Cooling Laundries

Laundries have one of the most severe environments in which direct evaporative air cooling is applied, because heat is produced not only by the processing equipment, but by steam and water vapor as well. A properly designed direct evaporative cooler reduces the temperature in a laundry 5 to 10°F below the outdoor temperature. With only fan ventilation, laundries usually exceed the outdoor temperature by at least 10°F. Air distribution should be designed for a maximum throw of not more than 30 ft. A minimum circulated velocity of 100 to 200 fpm should prevail in the occupied space. Ducts can be located to discharge the air directly onto workers in exceptionally hot areas, such as pressing and ironing departments. For these outlets, manual control should be provided to direct the air where it is desired, with at least 500 to 1000 cfm at a target velocity of 600 to 900 fpm for each workstation.

Cooling Wood and Paper Products Facilities

Wood-processing plants and paper mills are good applications for evaporative cooling because of the high temperatures and gases associated with wood-processing equipment. Wood dust should be kept out of the recirculation sumps of evaporative coolers, because the dust contains microorganisms and worm larvae that will grow in sumps.

Because of the types of gases and particulates present in most paper plants, water-cooled systems are preferred over air-cooled systems. The most prevalent contaminant is wood dust. Chlorine gas, caustic soda, sulfur, hydrogen sulfide, and other compounds are also serious problems, because they accelerate the corrosion of steel and yellow metals. With more efficient air scrubbing, ambient air quality in and about paper mills has become less corrosive, allowing use of equipment with well-analyzed and properly applied coatings on coils and housings. Phosphor-free brazed coil joints should be used in areas where sulfur compounds are present.

Heat is readily available from processing operations and should be used whenever possible. Most plants have good-quality hot water and steam, which can be readily geared to unit heater, central station, or reheat use. Newer plant air-conditioning methods, including evaporative cooling, that use energy-conservation techniques (such as temperature stratification) lend themselves to this type of large structure. [Chapter 26](#) has further information on air-conditioning of paper facilities.

8. OTHER APPLICATIONS

Cooling Power-Generating Facilities

An appropriate air-cooling system can be selected once preliminary heating and cooling loads are determined and criteria are established for temperature, humidity, pressure, and airflow control. The same considerations for selection apply to power-generating facilities and industrial facilities.

Cooling Mines

[Chapter 29](#) describes evaporative cooling methods for mines.

Cooling Animals

The design criteria for farm animal environments and the need for cooling animal shelters are discussed in [Chapter 24](#). Direct evaporative cooling is ideally suited to farm animal shelters because 100% outdoor air is used. Fresh air removes odors and reduces the harmful effects of ammonia fumes. At night and in the spring and fall, direct evaporative cooling can also be used for ventilation.

Equipment should be sized to change the air in the shelter in 1 to 2 min, assuming the ceiling height does not exceed 10 ft. This flow rate usually keeps the shelter at or below 80°F. In addition, conditions can be improved with portable or packaged spot coolers.

For poultry housing, most applications require an air change every 0.75 to 1.5 min, with the majority at 1 min. Placing the fans at the ends or the center of the house, with the direct evaporative cooler located at the opposite end, creates a tunnel ventilation system with an air velocity of 300 to 500 fpm. Fans are generally selected for a total pressure drop of 0.125 in. of water, which means that the direct evaporative cooling media cannot have a pressure drop in excess of 0.075 in. of water. Thus, to prevent an inadequate volume of air being pulled through the poultry house, the designer must carefully size the media selected.

Using direct evaporative cooling for poultry broiler houses decreases bird mortality, improves feed conversion ratio, and increases the growth rate. Poultry breeder houses are evaporatively cooled to improve egg production and fertility during warm weather. Evaporative cooling of egg layers improves feed conversion, shell quality, and egg size. When the ambient outdoor temperature exceeds 100°F, evaporative cooling is often the only way to keep a flock alive. Direct evaporative cooling is also used to cool swine farrowing and gestation houses to improve production.

Produce Storage Cooling

Potatoes. Direct evaporative cooling for bulk potato storage should pass air directly through the pile. The ventilation and cooling system should provide 1.0 to 1.5 cfm/100 lb of potatoes. Average potato density is 45 lb/ft³ in the pile. Pile depths range from 12 to 20 ft, which creates a static pressure of 0.15 to 0.25 in. of water. Ventilation consists of fresh air inlets, return air openings, exhaust air openings, main air ducts, and lateral ducts with holes or slots to distribute air uniformly through the pile. Distribution ducts should be placed no farther apart than 80% of the potato pile depth, and should extend to within 18 in. of the storage walls. Ducts, the direct evaporative cooling media, and any refrigeration coils cause a static pressure ranging from 0.5 to 1.0 in. of water. Typically the total static pressure ranges from 0.75 to 1.25 in. of water, depending on the equipment. Air speed through each of the openings in the ventilation/cooling system should be as listed in [Table 5](#).

Direct evaporative cooling media should be 90 to 95% effective, depending on the climate. In arid regions, 95% effective media are recommended. In more humid climates, such as in the midwestern and eastern United States, 90%

effective media are commonly used. Air speed through the media should be 500 to 550 fpm to ensure high pad efficiency with low static-pressure penalty.

For more information, see [Chapter 37 of the 2022 ASHRAE Handbook—Refrigeration](#).

Apples. Direct evaporative cooling for apple storage without refrigeration should distribute cool air to all parts of the storage. The evaporative cooler may be floor-mounted or located near the ceiling in a fan room. Air should be discharged horizontally at ceiling level. Because the prevailing wet-bulb temperature limits the degree of cooling, a cooler with maximum reasonable size should be installed to reduce the storage temperature rapidly and as close to the wet-bulb temperature as possible. Generally, a cooler designed to exchange air every 3 min (20 air changes per hour) is the largest that can be installed. This capacity provides a complete air change every 1 to 1.5 min (40 to 60 air changes per hour) when the storage is loaded.

Table 5 Air Speeds for Potato Storage Evaporative Cooler

Opening	Minimum Speed, fpm	Maximum Speed, fpm	Desired Speed, fpm
Fresh air inlet	1000	1400	1200
Return air opening	1000	1400	1200
Exhaust opening	1000	1200	1100
Main duct	500	900	700
Lateral duct	750	1100	900
Slot	900	1300	1050

For further information on apple storage, see [Chapter 35 of the 2022 ASHRAE Handbook—Refrigeration](#).

Citrus. The chief purpose of evaporative-cooling fruits and vegetables is to provide an effective, inexpensive means of improving storage. However, it also serves a special function in the case of oranges, grapefruit, and lemons. Although mature and ready for harvest, citrus fruits are often still green. Color change (degreening) is achieved through a sweating process in rooms equipped with direct evaporative cooling. Air with a high relative humidity and a moderate temperature is circulated continuously during the operation. Ethylene gas, the concentration depending on the variety and intensity of green pigment in the rind, is discharged into the rooms. Ethylene destroys chlorophyll in the rind, allowing the yellow or orange color to become evident. During degreening, a temperature of 70°F and a relative humidity of 88 to 90% are maintained in the sweat room. (In the Gulf States, 82 to 85°F with 90 to 92% rh is used.) The evaporative cooler is designed to deliver 11 cfm per pound of fruit.

Direct and indirect evaporative cooling is also used as a supplement to refrigeration in the storage of citrus fruit. Citrus storage requires refrigeration in the summer, but the required conditions can often be obtained using evaporative cooling during the fall, winter, and spring when the outdoor wet-bulb temperature is low. For further information, see [Chapter 36 of the 2022 ASHRAE Handbook—Refrigeration](#).

Cooling Greenhouses

Proper regulation of greenhouse temperatures during the summer is essential for developing high-quality crops. The principal load on a greenhouse is solar radiation, which at sea level at about noon in the temperate zone is approximately 200 Btu/h · ft². Smoke, dust, or heavy clouds reduce the radiation load. [Table 6](#) gives solar radiation loads for representative cities in the United States. Note that the values cited are average solar heat gains, not peak loads. Temporary rises in temperature inside a greenhouse can be tolerated; an occasional rise above design conditions is not likely to cause damage.

Not all solar radiation that reaches the inside of the greenhouse becomes a cooling load. About 2% of the total solar radiation is used in photosynthesis. Transpiration of moisture varies by crop, but typically uses about 48% of the solar radiation. This leaves 50% to be removed by the cooler. Example 2 shows a method for calculating the size of a greenhouse evaporative cooling system.

Example 2.. A direct evaporative cooler is to be installed in a 50 by 100 ft greenhouse. Design conditions are 92°F and 73°F wb, and average solar radiation is 138 Btu/h · ft². An indoor temperature of 90°F db must not be exceeded at design conditions.

Solution: The direct evaporative air cooler is assumed to have a saturation effectiveness of 80%. [Equation \(2\)](#) may be used to determine the dry-bulb temperature of the air leaving the direct evaporative cooler:

$$t_2 = 92 - \frac{80}{100} (92 - 73) = 77^\circ\text{F}$$

The following equation, a modification of [Equation \(1\)](#), may be used to calculate the airflow rate that must be supplied by the direct evaporative cooler:

$$Q_{ra} = \frac{0.5 A I_t}{60 \rho c_p} \quad (4)$$

where

- A = greenhouse floor area, ft²
 I_t = total incident solar radiation, Btu/h · ft² of receiving surface
 $60\rho c_p$ = density times specific heat of air times 60 min/h ≈ 1.0 Btu/ft³ · °F at design conditions

For this problem

$$Q_{ra} = \frac{0.5 \times 50 \times 100 \times 138}{1.0(90 - 77)} = 26,500 \text{ cfm}$$

Table 6 Three-Year Average Solar Radiation for Horizontal Surface During Peak Summer Month

City	Btu/h · ft ²	City	Btu/h · ft ²
Albuquerque, NM	198	Lemont, IL	142
Apalachicola, FL	170	Lexington, KY	170
Astoria, OR	132	Lincoln, NE	150
Atlanta, GA	158	Little Rock, AR	148
Bismarck, ND	140	Los Angeles, CA	162
Blue Hill, MA	128	Madison, WI	138
Boise, ID	155	Medford, OR	170
Boston, MA	125	Miami, FL	153
Brownsville, TX	175	Midland, TX	177
Caribou, ME	115	Nashville, TN	154
Charleston, SC	152	Newport, RI	138
Cleveland, OH	152	New York, NY	140
Columbia, MO	153	Oak Ridge, TN	148
Columbus, OH	127	Oklahoma City, OK	165
Davis, CA	184	Phoenix, AZ	200
Dodge City, KS	184	Portland, ME	133
East Lansing, MI	132	Prosser, WA	176
East Wareham, MA	132	Rapid City, SD	152
El Paso, TX	195	Richland, WA	137
Ely, NV	175	Riverside, CA	176
Fort Worth, TX	176	St. Cloud, MN	132
Fresno, CA	188	San Antonio, TX	176
Gainesville, FL	156	Santa Maria, CA	188
Glasgow, MT	152	Sault Ste. Marie, MI	138
Grandby, CO	149	Sayville, NY	148
Grand Junction, CO	173	Schenectady, NY	117
Great Falls, MT	150	Seabrook, NJ	135
Greensboro, NC	155	Seattle, WA	117
Griffin, GA	164	Spokane, WA	139
Hatteras, NC	177	State College, PA	141
Indianapolis, IN	140	Stillwater, OK	167
Inyokern, CA	218	Tallahassee, FL	134
Ithaca, NY	145	Tampa, FL	167
Lake Charles, LA	160	Upton, NY	148




Figure 22. Schematics for 100% Outdoor Air Used in Hospital

Horizontal illumination from the direct rays of noonday summer sun with clear sky can be as much as 10,000 footcandles (fc); under clear glass, this is approximately 8500 fc. Crops such as chrysanthemums and carnations grow best in full sun, but many foliage plants, such as gloxinias and orchids, do not need more than 1500 to 2000 fc. Solar radiation is nearly proportional to light intensity. Thus, the greater the amount of shade, the smaller the cooling capacity required. A value of 100 fc is approximately equivalent to 3 Btu/h · ft². Although atmospheric conditions such as clouds and haze affect the relationship, this is a safe conversion factor. This relationship should be used instead of [Table 5](#) when illumination can be determined by design or measurement.

Direct evaporative cooling for greenhouses may be under either positive or negative pressure. Regardless of the type of system used, the length of air travel should not exceed 160 ft. The temperature rise of the cool air limits the throw to this value. Air movement must be kept low because of possible mechanical damage to the plants, but it should generally not be less than 100 fpm in areas occupied by workers.

9. CONTROL STRATEGY TO OPTIMIZE ENERGY RECOVERY

[Figures 22A](#) and [22B](#) show a heat pipe air-to-air heat exchanger used in a hospital for winter heat recovery and summer indirect (dry) evaporative cooling. The heat pipe has a double-walled partition between the clean outdoor air (OA) flow and the contaminated building exhaust air (EA). With this partition, leakage from the EA side of the heat exchanger to the supply air (SA) side is eliminated and fans may be positioned as shown for blow-through exhaust and draw-through supply. The heat pipe has a direct spray manifold on the building return air side of the heat exchanger for indirect evaporative cooling. The spray pump is located in a water sump below the wet side of the heat pipe and uses recirculated water from the sump to wet the heat pipe. Potable makeup water is supplied to replace the water evaporated in the indirect cooling process along with wasted water required to maintain dissolved solids in the sump at acceptable levels. Using the building return air wet-bulb condition of 60 to 65°F, the summer cooling effect is greatly increased over dry-to-dry heat recovery.

The operation of both outdoor (OA) and exhaust air (EA) face and bypass dampers, working in concert with supply and return fan variable-frequency drives (VFD), allow parasitic fan static pressure losses to be minimized during favorable climatic conditions. [Figure 22B](#) shows a total bypass of the heat exchanger in the range of ambient temperatures of 55 to 65°F. The value of energy recovered is exceeded by the fan energy penalty during these outdoor air temperatures.

10. AIR CLEANING AND SOUND ATTENUATION

Evaporative coolers can effectively improve IAQ in many ways. Their similarity to wet scrubbers means they can remove particulates and soluble gases. Direct evaporative coolers of all types perform some air cleaning. Rigid-media direct evaporative coolers are effective at removing particles down to about 1 μm . Air washers are effective down to about 10 μm .

The dust removal efficiency of direct evaporative coolers depends largely on the size, density, wettability, and solubility of the dust particles. Larger, more wettable particles are the easiest to remove. Separation is largely a result of the impingement of particles on the wetted surface of the eliminator plates or on the surface of the media. Because the force of impact increases with the size of the solid, the impact (together with the adhesive quality of the wetted surface) determines the cooler's usefulness as a dust remover. [Table 7](#) gives an overview of particle removal efficiency for different filtration media depths.

The standard low-pressure spray is relatively ineffective in removing most atmospheric dusts. Direct evaporative coolers are of little use in removing soot particles because their greasy surface will not adhere to the wet plates or media. Direct evaporative coolers are also ineffective in removing smoke, because the small particles (less than 1 μm) do not impinge with sufficient impact to pierce the water film and be held on the media. Instead, the particles follow the air path between the media surfaces.

In the case of cross-corrugated media, the particles are removed from the media by the recirculated water. In locations with high particulate contamination, the sump and water distribution system should be flushed at least quarterly. If the particulate contains organic matter, it can contribute to biological growth on the media.

Control of Gaseous Contaminants

When used in a makeup air system comprised of a mixture of outdoor air and recirculated air, direct evaporative coolers function as scrubbers and reduce some gaseous contaminants found in outdoor air. These contaminants may concentrate in the recirculating water, so some water must be bled off. For more information regarding control of gaseous contaminants, see [Chapter 46](#).

Table 7 Particulate Removal Efficiency of Rigid Media at 500 fpm Air Velocity

Media Depth, in.	Particle Sizes, μm					
	0.3 to 0.5	0.5 to 0.7	0.7 to 1	1 to 5	5 to 10	>10
6	1.7%	21.3%	25.6%	43.6%	46.2%	61.3%
300	9.6%	31.8%	55.4%	87.2%	96.5%	97.3%

Source: Data courtesy of Munters Corporation.

Evaporative coolers near sources of airborne nitric acid, chlorine, or ammonia absorb these chemicals, which can damage the cooler. The amount of soluble gases cleaned from the air depends on the air/water mixing, retention time, the water's pH, and the bleed rate. When exposed to soluble gases, evaporative coolers should be operated with a high bleed rate.

Table 8 Insertion Loss for 12 in. Depth of Rigid Media at 550 fpm Air Velocity, dB

Media Orientation	Octave Band Center Frequency, Hz							
	63	125	250	500	1000	2000	4000	8000
Dry, forward flow	2	1	2	5	4	5	10	14
Reverse flow	4	1	2	4	5	4	9	13
Wet, forward flow	1	0	3	3	3	4	6	9
Reverse flow	3	1	3	3	3	3	4	8

Source: Data courtesy of Munters Corporation.

Ozone levels of the airstream can be reduced using evaporative coolers and air washers. Ozone is fairly unstable in a watery solution, decaying to ordinary diatomic oxygen. The stability of ozone absorbed in water depends on water temperature, ozone concentration, and length of holding time. Higher room humidity can vastly improve the rate at which it decays back to oxygen (Sterling et al. 1985).

Legionnaires' Disease. There have been no known cases of Legionnaires' disease with air washers or wetted-media evaporative air coolers. This can be attributed to the low temperature of the recirculated water, which is not conducive to *Legionella* bacteria growth, as well as the absence of aerosolized water carryover that could transmit the bacteria to a host (ASHRAE *Guideline* 12-2000).

Evaporative cooler media can attenuate sound attenuation somewhat. This insertion loss varies, depending on whether the media is wet or dry and whether the sound is traveling counter to (reverse flow) or with (forward flow) the airstream. Sound attenuation for 12 in. depth of rigid media can be found in [Table 8](#). Components in the path of airflow in an air-handler plenum or duct provide some sound attenuation; one of the more effective at reducing sound

pressure levels is the rigid-media direct evaporative cooler (DEC). Periannan (2013) performed tests in accordance with ASTM *Standard* E477-90 to measure insertion losses (1) with airflow in the direction of sound and (2) with reverse airflow. Measurements were also made at different velocities and for different media depths. As [Table 8](#) shows, a rigid-media DEC is quite effective in reducing low-frequency noise levels, which are usually the most difficult to reduce. Rigid media should likely not be used purely as a sound attenuator, but noise reduction can be an additional benefit when these types are selected.

11. ECONOMIC FACTORS

Design of direct and indirect evaporative cooling systems and sizing of equipment are based on the application's load requirements and on the local dry- and wet-bulb design conditions, which may be found in [Chapter 14 of the 2021 ASHRAE Handbook—Fundamentals](#) (with extended data and locations on the CD accompanying that volume, and in the Handbook Online version of that chapter). Total energy use for a specific application during a set period may be forecasted by using annual weather data. Dry-bulb and mean coincident wet-bulb temperatures, with the hours of occurrence, can be summarized and used in a modified bin procedure. The calculations must reflect the hours of use, conditions of load, and occupancy. Because of annual variations in dry- and wet-bulb temperatures and the effect of increasing cooling capacity with decreasing wet-bulb temperatures, bin calculations using mean coincident wet-bulb temperatures generally produce conservative results. When comparing various cooling systems, cost analysis should include annual energy reduction at the applicable electrical rate, plus anticipated energy cost escalation over the expected life.

Many areas have time-of-day electrical metering as an incentive to use energy during off-peak hours when rates are lowest. Reducing air-conditioning kilowatt demand is especially important in areas with ratcheted demand rates (Scofield and DesChamps 1980). Thermal storage using ice banks or chilled-water storage may be used as part of a multistage evaporatively refrigerated cooler to combine the energy-saving advantages of evaporative cooling and off-peak savings of thermal storage (Eskra 1980).

Direct Evaporation Energy Saving

Direct evaporative cooling may be used in all climates to save cooling and humidification energy. In humid climates, the benefits of direct evaporation are realized during periods when outdoor air is warm and dry, but cooling savings are unlikely to be realized during peak design conditions. In more arid areas, direct evaporative cooling may partially or fully offset mechanical cooling at peak load conditions. Humidification energy savings may be realized during the heating season when outdoor air is used to provide cooling and humidification. If properly controlled, direct evaporative cooling can use waste heat otherwise rejected from buildings when outdoor air is used for cooling.

Indirect Evaporation Energy Saving

Indirect evaporative cooling may be used in all climates to save cooling and, in some applications, heating energy. In humid climates, indirect evaporative cooling may be used throughout the cooling cycle to precool outdoor air. Indirect evaporative cooling can be used to extend the range of 100% outdoor air ventilation to both higher and lower temperatures, and to increase the percentage of outdoor air a system can support at any given temperature through heat recovery. In high-humidity areas, indirect evaporative cooling may be used to (1) partially offset mechanical cooling requirements at peak load conditions and (2) provide better control over low-load humidity conditions by allowing use of smaller refrigeration equipment to provide ventilation over a wider range of outdoor air conditions. The cost of heating may be reduced when operating below temperatures at which minimum outdoor air quantities exceed the rates of ventilation required for free cooling by using heat recovered from building exhausts.

Water Cost for Evaporative Cooling

Typically, domestic service water is used for evaporative cooling to avoid excessive scaling and associated problems with poor water quality. In designing evaporative coolers, the cost of water treatment is included in the overall project cost. However, water cost is typically ignored for evaporative coolers because it is usually an insignificant part of the operational cost. Depending on the ambient dry-bulb temperature and wet-bulb depression for a specific location, the cost of water could become a significant part of the operational cost, because the greater the differential between dry- and wet-bulb temperatures, the greater the amount of water evaporated (Mathur 1997, 1998).

12. PSYCHROMETRICS

[Figure 23](#) shows the two-stage (indirect/direct) process applied to nine cities in the western United States. The examples indicated are primarily shown for arid areas, but the principles also apply to moderately humid and humid areas when weather conditions allow. For each city indicated, the entering conditions to the first-stage indirect unit are at or near the 0.4% design dry- and wet-bulb temperatures in [Chapter 14 of the 2021 ASHRAE Handbook—](#)

Fundamentals. Although higher effectiveness can be achieved for both the indirect and direct evaporative processes modeled, the effectiveness ratings are 60% for the first (indirect) stage and 90% for the second (direct) stage. Leaving air temperatures range from 52 to 70°F, with leaving conditions approaching saturation.




Figure 23. Two-Stage Evaporative Cooling at 0.4% Design Condition in Various Cities in Western United States




Figure 24. Final Room Design Conditions After Two-Stage Evaporative Cooling

Figure 24 projects space conditions in each city at 78°F db for these second-stage supply temperatures based on a 95% room sensible heat factor (i.e., room sensible heat/room total heat). Except in Wichita, Los Angeles, and Seattle, room conditions can be maintained in the comfort zone without a refrigerated third stage. But even in these cities, third-stage refrigeration requirements are sharply reduced as compared to conventional mechanical cooling. However, **Figures 23** and **24** indicate the need to consider the following factors when deciding whether to include a third cooling stage:

- As the room sensible heat factor decreases, the supply air temperature required to maintain a given room condition decreases.

- As supply air temperature increases, the supply air quantity must increase to maintain space temperature, which results in higher air-side initial cost and increased supply air fan power.
- A decrease in the required room dry-bulb temperature requires an increase in the supply air quantity. For a given room sensible heat factor, a decrease in room dry-bulb temperature may cause the relative humidity to exceed the comfort zone.
- The suggested 0.4% entering design (dry-bulb/mean wet-bulb) conditions are only one concern. Partial-load conditions must also be considered, along with the effect (extent and duration) of spike wet-bulb temperatures. Mean wet-bulb temperatures can be used to determine energy use of the indirect/direct system. However, the higher wet-bulb temperature spikes should be considered to determine their effect on room temperatures.

An ideal condition for maximum use with minimum energy consumption of a two- and three-stage indirect/direct system is a room sensible heat factor of 90% and higher, a supply air temperature of 60°F, and a dry-bulb room design temperature of 78°F. In many cases, third-stage refrigeration is required to ensure satisfactory dry-bulb temperature and relative humidity. Example 3 shows a method for determining the refrigeration capacity for three-stage cooling. [Figure 25](#) is a psychrometric diagram of the process.

Example 3. Assume the following:

- Supply air quantity = 24,000 cfm; supply air temperature = 60°F
- Design condition = 99°F db and 68°F wb
- Effectiveness of indirect unit = 60%;
- Effectiveness of direct unit = 90%

Using [Equation \(2\)](#), the leaving air state from the indirect unit (first stage) is

$$99 - 0.60(99 - 68) = 80.4^\circ\text{F db (61.8}^\circ\text{F wb)}$$

Using [Equation \(2\)](#), the leaving air state from the direct unit (second stage) is

$$80.4 - 0.90(80.4 - 61.8) = 63.7^\circ\text{F db (61.8}^\circ\text{F wb)}$$

Calculate booster refrigeration capacity to drop the supply air temperature from 63.7°F to the required 60°F.

If the refrigerating coil is located ahead of the direct unit,

$$\text{Btu cooling} = \frac{60(h_1 - h_2)(\text{supply air, cfm})}{\text{Specific volume dry air at leaving air condition}}$$

With numeric values of enthalpies h_1 and h_2 (in Btu/lb) and the specific volume of air (in ft³/lb_{da}) taken from ASHRAE psychrometric chart no. 1, the cooling load is calculated as follows:

$$60(27.6 - 25.5)24,000/13.78 = 219,400 \text{ Btu/h} = 18.3 \text{ tons}$$

The load for a coil located in the leaving air of the direct unit is

$$60(27.6 - 25.5)24,000/13.43 = 225,000 \text{ Btu/h} = 18.8 \text{ tons}$$

Depending on the booster coil's location, the preceding calculations can be used to determine third-stage refrigeration capacity and to select a cooling coil.

Using this example, refrigeration sizing can be compared to conventional refrigeration without staged evaporative cooling. Assuming mixed air conditions to the coil of 81°F db and 66.5°F wb, and the same 60°F db supply air as shown in [Figure 24](#), the refrigerated capacity is

$$60(31.1 - 25.7)24,000/13.31 = 584,200 \text{ Btu/h} = 48.7 \text{ tons}$$

This represents an increase of 30.4 tons. The staged evaporative effect reduces the required refrigeration by 62.4%.




Figure 25. Psychrometric Diagram of Three-Stage Evaporative Cooling Example 3

13. ENTERING AIR CONSIDERATIONS

The effectiveness of direct and indirect evaporative cooling depends on the entering air condition. Where outdoor air is used in a direct evaporative cooler, the design is affected by the prevailing outdoor dry- and wet-bulb temperatures as well as by the application. Where conditioned exhaust air is used as secondary air for indirect evaporative cooling, the design is less affected by local weather conditions, which makes evaporative cooling viable in hot and humid environments.

For example, in arid areas like Reno, Nevada, a simple, direct evaporative cooler with an effectiveness of 80% provides a leaving air temperature of 68°F when dry- and wet-bulb temperatures of the entering air are 96 and 61°F, respectively. In the same location, adding an indirect evaporative precooling stage with an effectiveness of 80% produces a leaving air condition of 53.6°F.

In a location such as Atlanta, Georgia, with design temperatures of 94 and 74°F, the same direct evaporative cooler could supply only 78°F. This could be reduced to 71.1°F by adding an 80% effective indirect evaporative precooling stage (Supple 1982). If exhaust air from the building served is provided at a stable 75°F db and 62.5°F wb, an indirect evaporative precooler could deliver air at 68.8°F, substantially reducing outdoor air cooling loads. Under these conditions, indirect evaporative precoolers can provide limited dehumidification capabilities.

Long-term benefits to owners of direct evaporative cooling systems include a 20 to 40% reduction of utility costs compared to mechanical refrigeration (Watt 1988). When used to control humidity, the reduction in cooling and humidification energy use ranges from 35 to 90% (Lentz 1991). Although direct evaporative cooling does not reduce peak cooling loads except in arid areas, it can reduce both total cooling energy and humidification energy requirements in a wide range of environments, including hot and humid ones.

Indirect evaporative cooling lowers the temperature (both dry- and wet-bulb) of the air entering a direct evaporative cooling stage and, consequently, lowers the supply air temperature. When used with mechanical cooling on 100% outdoor air systems, with the secondary air taken from the conditioned space, the precooling effect may reduce peak cooling loads between 50 and 70%. Total cooling requirements may be reduced between 40 and 85% annually, depending on location, system configuration, and load characteristics. Indirect evaporative coolers may also function as heat recovery systems, which expands the range of conditions over which the process is used. Indirect evaporative cooling, when used with building exhaust air, is especially effective in hot and humid climates.

REFERENCES

ASHRAE members can access *ASHRAE Journal* articles and ASHRAE research project final reports at technologyportal.ashrae.org. Articles and reports are also available for purchase by nonmembers in the online ASHRAE Bookstore at www.ashrae.org/bookstore.

ASHRAE. 2000. Minimizing the risk of Legionellosis associated with building water systems. *Guideline* 12-2000.

- ASHRAE. 2013. Ventilation for acceptable indoor air quality. ANSI/ASHRAE *Standard* 62.1-2013.
- Colvin, T.D. 1995. Office tower reduces operating costs with two-stage evaporative cooling system. *ASHRAE Journal* 37(3):23-24.
- Crow, L.W. 1972. Weather data related to evaporative cooling. Research Report 2223. *ASHRAE Transactions* 78(1):153-164.
- Des Champs, N.H., and K. Dunnivant. 2014. Free cooling technologies. Ch. 25 in *Data center handbook*, H. Geng, ed. John Wiley & Sons, New York
- Ecodyne Corp. 1980. *Weather data handbook*. McGraw-Hill, New York.
- English, T., D. Castillo, and A. Darwich. 2015. The natural experiment in California hospital ventilation rates. ASHRAE Winter Conference, *Paper* CH-15-C018.
- Eskra, N. 1980. Indirect/direct evaporative cooling systems. *ASHRAE Journal* 22(5):22.
- Felver, T.G., M. Scofield, and K. Dunnivant. 2001. Cooling California's computer centers. *HPAC Magazine*, pp. 60-61.
- Karim, Y.G., M.K. Ijaz, S.A. Sattar, and C. M. Johnson-Lussenburg. 1985. Effect of relative humidity on the airborne survival of rhinovirus-14. *Canadian Journal of Microbiology* 31(11):1058-1061. [dx.doi.org/10.1139/m85-199](https://doi.org/10.1139/m85-199).
- Lentz, M.S. 1991. Adiabatic saturation and VAV: A prescription for economy and close environmental control. *ASHRAE Transactions* 97(1):477-485. *Paper* NY-91-04-3.
- Lstiburek, J. 2017. Magic and mystery of the water molecule: It's all relative. *ASHRAE Journal* 59(9):68-74.
- Mathur, G.D. 1990. Indirect evaporative cooling using two-phase thermosiphon loop heat exchangers. *ASHRAE Transactions* 96(1):1241-1249. *Paper* AT-90-18-3.
- Mathur, G.D. 1997. Performance enhancement of existing air conditioning systems. *Intersociety Energy Conversion Engineering Conference, American Institute of Chemical Engineers* 3:1618-1623.
- Mathur, G.D. 1998. Predicting yearly energy savings using bin weather data with heat pipe exchangers with indirect evaporative cooling. Intersociety Energy Conversation Engineering Conference, *Paper* 98-IECEC-049.
- Mathur, G.D., and D.Y. Goswami. 1995. Indirect evaporative cooling retrofit as a demand side management strategy for residential air conditioning. *Intersociety Energy Conversion Engineering Conference, ASME* 2:317-322.
- Mathur, G.D., D.Y. Goswami, and S.M. Kulkarni. 1993. Experimental investigation of a residential air conditioning system with an evaporatively cooled condenser. *Journal of Solar Energy Engineering* 115:206-211.
- Milton, D.K., P.M. Glencross, and M.D. Walters. 2000. Risk of sick leave associated with outdoor air supply rates, humidification and occupant complaints. *Indoor Air* 10(4):212-221. [dx.doi.org/10.1034/j.1600-0668.2000.010004212.x](https://doi.org/10.1034/j.1600-0668.2000.010004212.x).
- Pantelic, J., and K.W. Tham. 2013. Adequacy of air change rate as the sole indicator of an air distribution system's effectiveness to mitigate airborne infectious disease transmission caused by a cough release in the room with overhead mixing ventilation: A case study. *HVAC&R Research (now Science and Technology for the Built Environment)* 19(8):947-961. [dx.doi.org/10.1080/10789669.2013.842447](https://doi.org/10.1080/10789669.2013.842447).
- Periannan, V. 2013. Humidification, filtration and sound attenuation benefits of rigid media direct evaporative cooling systems while providing energy savings. Presented at ASHRAE Annual Conference, Denver, CO. *Paper* DE-13-C049.
- Risbeck, M.J., M.Z. Bazant, Z. Jiang, Y.M. Lee, K.H. Drees, and J.D. Douglas. 2022. Airborne disease transmission risk and energy impact of HVAC mitigation strategies. *ASHRAE Journal* 64(5):12-25.
- Scofield, C.M. 1986. The heat pipe used for dry evaporative cooling. *ASHRAE Transactions* 92(1B):371-381. *Paper* SF-86-08-3.
- Scofield, C.M. 1994. California classroom VAV with IAQ and energy savings, too. *HPAC Magazine*, p. 89.
- Scofield, C.M. 2020. VAV+IAQ: Cure for the common cold. *HPAC Engineering*, p. 12. www.hpac.com/iaq-ventilation/article/21120626/vav-ieq-iaq-ahu-energy-efficiency-hvacr-humidity.
- Scofield, M., and J. Bergman. 1997. ASHRAE *Standard* 62R: A simple method of compliance. *HPAC Magazine* (October):67.
- Scofield, M., and N. Des Champs. 1980. EBTR compliance and comfort too. *ASHRAE Journal* 22(6):61.
- Scofield, C.M., and N.H. Des Champs. 1984. Indirect evaporative cooling using plate-type heat exchangers. *ASHRAE Transactions* 90(1B):148-153. *Paper* AT-84-03-2.
- Scofield, M., and E. Sterling. 1992. Dry climate evaporative cooling with refrigeration backup. *ASHRAE Journal* 34(6):49.
- Scofield, M., and V. Periannan. 2015. A VAV system heat recovery economizer to furnish free humidification and exceed ASHRAE *Standard* 62.1 ventilation requirements in winter. Presented at ASHRAE Annual Conference, Atlanta, GA. *Paper* AT-15-C065.
- Scofield, C.M., N. Des Champs, and T. Weaver. 2016. Variable air volume system heat recovery economizer: Exceeding *Standard* 62.1 requirements. *ASHRAE Journal* 58(5):34-45.
- Seppanen, O., W.J. Fisk, and Q.H. Lei. 2005. Ventilation and performance in office work. *Indoor Air* 16(1):28-36. [dx.doi.org/10.1111/j.1600-0668.2005.00394.x](https://doi.org/10.1111/j.1600-0668.2005.00394.x).
- Sterling, E.M., A. Arundel, and T.D. Sterling. 1985. Criteria for human exposure to humidity in occupied buildings. *ASHRAE Transactions* 91(1B):611-622. *Paper* CH-85-13-1.
- Stewart, W.E., Jr. 1999. *Design guide for combustion turbine inlet air cooling systems*. ASHRAE.
- Supple, R.G. 1982. Evaporative cooling for comfort. *ASHRAE Journal* 24(8):42.

- Tang, J.W. 2009. The effect of environmental parameters on the survival of airborne infectious agents. *Journal of The Royal Society Interface* 6(6). doi.org/10.1098/rsif.2009.0227.focus.
- Taylor, S. 2014. Infectious microorganisms do not care about your existing policies. *Engineered Systems*, p. 42.
- Taylor, S. 2021. Monitoring IAQ and occupant health. *ASHRAE Journal* 63(10).
- Taylor, S., C.M. Scofield, and P.T. Graef. 2020. Improving IEQ to reduce transmission of airborne pathogens in cold climates. *ASHRAE Journal* 62(9):30-47.
- Watt, J.R. 1988. Power cost comparisons: Evaporative vs. refrigerative cooling. *ASHRAE Transactions* 94(2):1108-1115. Paper OT-88-04-3.
- Wu, H., and J.L. Yellott. 1987. Investigation of a plate-type indirect evaporative cooling system for residences in hot and arid climates. *ASHRAE Transactions* 93(1):1252-1260. Paper NY-87-12-2.

BIBLIOGRAPHY

- Arens, E., H. Zhang, T. Hoyt, S. Kaam, J. Goins, F. Bauman, Y. Zhai, T. Webster, B. West, G. Paliaga, J. Stein, R. Seidl, B. Tullym, J. Rimmer, and J. Torftum. 2015. Thermal and air quality acceptability in buildings that reduce energy by reducing minimum airflows from overhead diffusers. ASHRAE Research Project RP-1515, *Final Report*.
- ASHRAE. 2004. Thermal environmental conditions for human occupancy. ANSI/ASHRAE *Standard* 55-2004.
- Peterson, J.L., and B.D. Hunn. 1992. Experimental performance of an indirect evaporative cooler. *ASHRAE Transactions* 98(2):15-23. Paper 3598.
- Scofield, M., and J. Taylor. 1986. A heat pipe economy cycle. *ASHRAE Journal* 28(10):35-40.
- Scofield, C.M., and T. Weaver. 2008. Data center cooling: Using wet bulb economizers. *ASHRAE Journal* 50(8):52-54, 56-58.
- Stewart, W.E., Jr., and L.A. Stickler. 1999. Designing for combustion turbine inlet air cooling. *ASHRAE Transactions* 105(1). Paper 4242.
- Strock, C., ed. 1959. *Handbook of air conditioning, heating & ventilation*. Industrial Press, New York.
- Watt, J.R. 1997. *Evaporative air conditioning handbook*, 3rd ed. Chapman & Hall, New York.
- Yellott, J.I., and J. Gamero. 1984. Indirect evaporative air coolers for hot, dry climates. *ASHRAE Transactions* 90(1B):139-147. Paper AT-84-03-1.
-

The preparation of this chapter is assigned to TC 5.7, Evaporative Cooling.