

| 2021 ASHRAE Handbook - Fundamentals (SI)                          |                        |                 |                               |         |                    |              |      |  |                       |            |              |            |                       |                      |                |      |      |
|---|------------------------|-----------------|-------------------------------|---------|--------------------|--------------|------|--|-----------------------|------------|--------------|------------|-----------------------|----------------------|----------------|------|------|
| RESISTENCIA, ARGENTINA (WMO: 871550)                              |                        |                 |                               |         |                    |              |      |  |                       |            |              |            |                       |                      |                |      |      |
| Lat:27.4389S  |                        | Long:59.0461W   |                               | Elev:52 |                    | StdP: 100.70 |      | Time zone:-3.00 (W03)                              |                       |            | Period:94-19 |            | WBAN:99999            |                      |                |      |      |
| Annual Heating, Humidification, and Ventilation Design Conditions |                        |                 |                               |         |                    |              |      |  |                       |            |              |            |                       |                      |                |      |      |
| Coldest Month   | Heating DB             |                 | Humidification DP/MCDB and HR |         |                    |              |      |  | Coldest month WS/MCDB |            |              |            | MCWS/PCWD to 99.6% DB |                      | WSF            |      |      |
|   |                        |                 | 99.6%                         |         |                    | 99%          |      |  | 0.4%                  |            | 1%           |            | MCWS                  | PCWD                 |                |      |      |
|   | 99.6%                  | 99%             | DP                            | HR      | MCDB               | DP           | HR   | MCDB   | WS                    | MCDB       | WS           | MCDB       |                       |                      | MCWS           | PCWD |      |
| 7   | 2.0                    | 3.9             | -1.2                          | 3.4     | 8.7                | 0.2          | 3.9  | 9.5  | 9.6                   | 20.5       | 8.7          | 19.7       | 1.3                   | 230                  | 0.369          |      |      |
| Annual Cooling, Dehumidification, and Enthalpy Design Conditions  |                        |                 |                               |         |                    |              |      |  |                       |            |              |            |                       |                      |                |      |      |
| Hottest Month   | Hottest Month DB Range | Cooling DB/MCWB |                               |         |                    |              |      | Evaporation WB/MCDB                                |                       |            |              |            |                       | MCWS/PCWD to 0.4% DB |                |      |      |
|   |                        | 0.4%            |                               | 1%      |                    | 2%           |      | 0.4%   |                       | 1%         |              | 2%         |                       | MCWS                 | PCWD           |      |      |
|   |                        | DB              | MCWB                          | DB      | MCWB               | DB           | MCWB | WB   | MCDB                  | WB         | MCDB         | WB         | MCDB                  |                      |                | MCWS | PCWD |
| 1   | 11.5                   | 37.2            | 24.2                          | 36.0    | 24.5               | 34.8         | 24.4 | 27.2   | 32.7                  | 26.6       | 32.0         | 26.1       | 31.5                  | 4.9                  | 20             |      |      |
| Dehumidification DP/MCDB and HR                                   |                        |                 |                               |         |                    |              |      |  | Enthalpy/MCDB         |            |              |            |                       |                      | Extreme Max WB |      |      |
| 0.4%  |                        |                 | 1%                            |         |                    | 2%           |      |  | 0.4%                  |            | 1%           |            | 2%                    |                      |                |      |      |
| DP  | HR                     | MCDB            | DP                            | HR      | MCDB               | DP           | HR   | MCDB   | Enth                  | MCDB       | Enth         | MCDB       | Enth                  | MCDB                 |                |      |      |
| 25.9  | 21.4                   | 30.2            | 25.1                          | 20.4    | 29.5               | 24.7         | 19.8 | 29.2   | 86.7                  | 32.7       | 83.8         | 32.3       | 81.3                  | 31.6                 | 35.2           |      |      |
| Extreme Annual Design Conditions                                  |                        |                 |                               |         |                    |              |      |  |                       |            |              |            |                       |                      |                |      |      |
| Extreme Annual WS   |                        |                 | Extreme Annual Temperature    |         |                    |              |      | n-Year Return Period Values of Extreme Temperature |                       |            |              |            |                       |                      |                |      |      |
|   |                        |                 | Mean                          |         | Standard deviation |              |      | n=5 years  |                       | n=10 years |              | n=20 years |                       | n=50 years           |                |      |      |
| 1%  | 2.5%                   | 5%              | Min                           | Max     | Min                | Max          | Min  | Max  | Min                   | Max        | Min          | Max        | Min                   | Max                  | Min            | Max  |      |
| 8.9   | 7.5                    | 6.7             | DB                            | -1.4    | 39.9               | 1.5          | 1.6  | -2.5   | 41.1                  | -3.4       | 42.0         | -4.2       | 42.9                  | -5.3                 | 44.0           |      |      |
|   |                        |                 | WB                            | -1.7    | 28.9               | 1.6          | 1.5  | -2.8   | 30.0                  | -3.8       | 30.9         | -4.6       | 31.8                  | -5.8                 | 32.9           |      |      |
| Monthly Climatic Design Conditions                                |                        |                 |                               |         |                    |              |      |  |                       |            |              |            |                       |                      |                |      |      |
|   |                        |                 | Annual                        | Jan     | Feb                | Mar          | Apr  | May  | Jun                   | Jul        | Aug          | Sep        | Oct                   | Nov                  | Dec            |      |      |
| Temperatures, Degree-Days and Degree-Hours                        | DBAvg                  | 21.6            | 27.2                          | 26.5    | 24.8               | 21.8         | 18.1 | 16.1   | 15.6                  | 17.4       | 19.4         | 22.3       | 23.8                  | 26.0                 |                |      |      |
|   | DBStd                  | 5.75            | 2.52                          | 2.88    | 3.06               | 3.87         | 4.41 | 5.01   | 5.45                  | 5.58       | 5.01         | 3.97       | 3.22                  | 2.89                 |                |      |      |
|   | HDD10.0                | 19              | 0                             | 0       | 0                  | 0            | 1    | 5  | 9                     | 4          | 1            | 0          | 0                     | 0                    |                |      |      |
|   | HDD18.3                | 446             | 0                             | 0       | 1                  | 12           | 61   | 103  | 124                   | 89         | 46           | 8          | 2                     | 0                    |                |      |      |
|   | CDD10.0                | 4237            | 534                           | 461     | 459                | 353          | 251  | 189  | 182                   | 233        | 282          | 383        | 413                   | 497                  |                |      |      |
|   | CDD18.3                | 1622            | 276                           | 228     | 201                | 116          | 53   | 37   | 38                    | 59         | 77           | 133        | 165                   | 239                  |                |      |      |
|   | CDH23.3                | 16246           | 3161                          | 2418    | 1886               | 908          | 347  | 204  | 284                   | 618        | 798          | 1272       | 1701                  | 2650                 |                |      |      |
| CDH26.7   | 7321                   | 1605            | 1151                          | 822     | 335                | 94           | 46   | 86   | 264                   | 349        | 553          | 732        | 1284                  |                      |                |      |      |
| Wind  | WSAvg                  | 3.0             | 2.8                           | 2.8     | 2.6                | 2.7          | 2.6  | 2.8  | 3.0                   | 3.4        | 3.7          | 3.6        | 3.2                   | 3.0                  |                |      |      |
| Precipitation   | PrecAvg                | 1351            | 165                           | 149     | 164                | 168          | 83   | 58   | 38                    | 45         | 59           | 122        | 154                   | 141                  |                |      |      |
|   | PrecMax                | 2218            | 441                           | 474     | 485                | 529          | 248  | 267  | 132                   | 152        | 215          | 337        | 612                   | 320                  |                |      |      |
|   | PrecMin                | 733             | 35                            | 13      | 12                 | 31           | 2    | 3  | 0                     | 0          | 0            | 23         | 20                    | 11                   |                |      |      |
|   | PrecStd                | 298             | 89                            | 85      | 108                | 126          | 64   | 52   | 28                    | 33         | 44           | 62         | 98                    | 81                   |                |      |      |
| Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures | 0.4%                   | DB              | 38.2                          | 38.2    | 37.1               | 34.2         | 32.0 | 30.1   | 31.0                  | 35.0       | 37.2         | 38.4       | 37.4                  | 38.1                 |                |      |      |
|   |                        | MCWB            | 24.6                          | 24.7    | 23.8               | 24.7         | 23.5 | 22.0   | 20.6                  | 21.0       | 21.8         | 24.1       | 24.6                  | 23.8                 |                |      |      |
|   | 2%                     | DB              | 36.8                          | 36.2    | 34.9               | 32.5         | 29.2 | 28.0   | 29.1                  | 32.2       | 34.0         | 34.9       | 34.2                  | 36.1                 |                |      |      |
|   |                        | MCWB            | 24.6                          | 24.9    | 24.8               | 24.3         | 22.6 | 21.7   | 20.6                  | 20.9       | 21.6         | 24.1       | 23.9                  | 24.9                 |                |      |      |
|   | 5%                     | DB              | 35.2                          | 34.5    | 33.0               | 30.7         | 27.0 | 25.9   | 27.0                  | 29.9       | 30.8         | 32.1       | 32.7                  | 34.6                 |                |      |      |
|   |                        | MCWB            | 24.7                          | 24.9    | 24.4               | 23.5         | 21.6 | 20.8   | 20.0                  | 20.4       | 20.9         | 23.1       | 23.3                  | 24.5                 |                |      |      |
| 10%   | DB                     | 33.8            | 32.8                          | 31.1    | 28.2               | 25.0         | 23.3 | 23.9   | 26.8                  | 27.9       | 29.5         | 30.9       | 32.9                  |                      |                |      |      |
|   | MCWB                   | 24.5            | 24.5                          | 23.7    | 22.4               | 20.7         | 19.8 | 18.8   | 19.3                  | 19.9       | 21.8         | 22.5       | 24.0                  |                      |                |      |      |
| Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures | 0.4%                   | WB              | 28.1                          | 28.0    | 27.2               | 26.6         | 24.9 | 23.5   | 22.7                  | 23.4       | 24.5         | 26.6       | 27.3                  | 27.7                 |                |      |      |
|   |                        | MCDB            | 33.8                          | 33.3    | 32.6               | 31.4         | 29.3 | 27.8   | 28.3                  | 31.0       | 32.3         | 33.1       | 32.6                  | 33.8                 |                |      |      |
|   | 2%                     | WB              | 27.1                          | 26.9    | 26.3               | 25.5         | 23.6 | 22.4   | 21.6                  | 22.1       | 23.2         | 25.2       | 25.8                  | 26.7                 |                |      |      |
|   |                        | MCDB            | 32.6                          | 31.9    | 31.6               | 30.2         | 27.6 | 26.4   | 27.0                  | 29.7       | 30.4         | 32.2       | 31.5                  | 32.4                 |                |      |      |
|   | 5%                     | WB              | 26.4                          | 26.2    | 25.6               | 24.6         | 22.5 | 21.4   | 20.4                  | 20.9       | 22.1         | 24.1       | 24.8                  | 26.1                 |                |      |      |
|   |                        | MCDB            | 31.8                          | 31.3    | 30.7               | 29.0         | 25.9 | 24.9   | 25.3                  | 27.9       | 28.6         | 31.0       | 30.3                  | 31.7                 |                |      |      |
| 10%   | WB                     | 25.8            | 25.5                          | 24.8    | 23.5               | 21.5         | 20.4 | 19.3   | 19.7                  | 20.9       | 23.0         | 23.8       | 25.4                  |                      |                |      |      |
|   | MCDB                   | 31.0            | 30.6                          | 29.2    | 27.0               | 24.3         | 23.2 | 23.5   | 26.1                  | 26.4       | 28.0         | 28.7       | 30.5                  |                      |                |      |      |

|                                     |             |       |       |       |       |       |       |       |       |       |       |       |       |       |
|-------------------------------------|-------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| <b>Mean Daily Temperature Range</b> |             | MDBR  | 11.5  | 10.7  | 10.6  | 10.1  | 10.2  | 10.1  | 11.6  | 12.9  | 12.6  | 11.2  | 11.6  | 11.4  |
|                                     | 5% DB       | MCDBR | 13.8  | 13.2  | 13.2  | 12.4  | 11.4  | 10.7  | 12.7  | 15.1  | 15.7  | 14.6  | 14.5  | 14.0  |
|                                     |             | MCWBR | 4.4   | 4.3   | 4.8   | 5.2   | 5.5   | 5.3   | 5.7   | 6.1   | 6.3   | 6.1   | 5.5   | 4.8   |
|                                     | 5% WB       | MCDBR | 10.7  | 10.2  | 10.6  | 10.2  | 9.4   | 9.7   | 11.7  | 13.7  | 13.0  | 12.4  | 10.9  | 10.8  |
| MCWBR                               |             | 4.4   | 4.5   | 4.9   | 4.9   | 4.9   | 5.4   | 6.2   | 6.3   | 6.3   | 6.1   | 5.5   | 4.8   |       |
| <b>Clear Sky Solar Irradiance</b>   | taub        |       | 0.411 | 0.409 | 0.397 | 0.393 | 0.375 | 0.390 | 0.384 | 0.476 | 0.545 | 0.478 | 0.403 | 0.413 |
|                                     | taud        |       | 2.394 | 2.406 | 2.427 | 2.412 | 2.421 | 2.366 | 2.363 | 2.052 | 1.885 | 2.143 | 2.372 | 2.373 |
|                                     | Ebn at noon |       | 933   | 918   | 898   | 850   | 819   | 776   | 799   | 753   | 749   | 845   | 934   | 934   |
|                                     | Edn at noon |       | 128   | 123   | 115   | 106   | 96    | 96    | 100   | 150   | 194   | 159   | 130   | 131   |
| <b>All-Sky Solar Radiation</b>      | RadAvg      |       | 6.79  | 6.20  | 5.33  | 4.12  | 3.23  | 2.66  | 3.17  | 3.89  | 4.70  | 5.47  | 6.56  | 6.77  |
|                                     | RadStd      |       | 0.56  | 0.42  | 0.37  | 0.44  | 0.40  | 0.23  | 0.28  | 0.35  | 0.57  | 0.58  | 0.48  | 0.48  |

Historical Trends

|                               | DBAvg | Heating |        | Cooling |       |       | Degree-Days |         |         |         |     |
|-------------------------------|-------|---------|--------|---------|-------|-------|-------------|---------|---------|---------|-----|
|                               |       | 99% DB  | 99% DP | 1% DB   | 1% WB | 1% DP | HDD10.0     | HDD18.3 | CDD10.0 | CDD18.3 |     |
| <b>Station Only</b>           | N/A   | N/A     | N/A    | +0.40   | N/A   | N/A   | N/A         | N/A     | N/A     | N/A     | N/A |
| <b>Regional (0 neighbors)</b> | N/A   | N/A     | N/A    | +0.43   | N/A   | N/A   | N/A         | N/A     | N/A     | N/A     | N/A |

|          |  |       |   |                       |   |
|----------|--|-------|---|-----------------------|---|
| CDDn     | Cooling degree-days base n°C, °C-day   | Lat   | Latitude, °                               | Period                | Years used to calculate the design conditions                             |
| CDHn     | Cooling degree-hours base n°C, °C-hour                                       | Long  | Longitude, °                              | Sd                    | Standard deviation of daily average temperature, °C                       |
| DB       | Dry bulb temperature, °C   | MCDB  | Mean coincident dry bulb temperature, °C  | StdP                  | Standard pressure at station elevation, kPa                               |
| DP       | Dew point temperature, °C  | MCDBR | Mean coincident dry bulb temp. range, °C  | taub                  | Clear sky optical depth for beam irradiance                               |
| Ebn,noon | Clear sky beam normal and diffuse horizontal irradiances at solar noon, W/m2 | MCDP  | Mean coincident dew point temperature, °C | taud                  | Clear sky optical depth for diffuse irradiance                            |
| Edh,noon |  | MCWB  | Mean coincident wet bulb temperature, °C  | Tavg                  | Average temperature, °C   |
| Elev     | Elevation, m   | MCWBR | Mean coincident wet bulb temp. range, °C  | Time Zone             | Hours ahead or behind UTC   |
| Enth     | Enthalpy, kJ/kg  | MCWS  | Mean coincident wind speed, m/s           | WB                    | Wet bulb temperature, °C  |
| HDDn     | Heating degree-days base n°C, °C-day   | MDBR  | Mean dry bulb temp. range, °C             | Hours 8/4 & 12.8/20.6 | Number of hours between 8 a.m. and 4 p.m with DB between 12.8 and 20.6 °C |
| PCWD     | Prevailing coincident wind direction, °, 0 = North, 90 = East                | WS    | Wind speed, m/s                           | HR                    | Humidity ratio, g of moisture per kg of dry air                           |