

2021 ASHRAE Handbook - Fundamentals (SI)															
SAN JULIAN, ARGENTINA (WMO: 879090)															
Lat:49.3083S		Long:67.8031W		Elev:62		StdP: 100.58			Time zone:-3.00 (W03)			Period:94-19		WBAN:99999	
Annual Heating, Humidification, and Ventilation Design Conditions															
Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
7	-4.1	-2.7	-9.8	1.6	9.8	-7.9	1.9	6.1	21.4	6.1	20.5	4.4	5.3	270	0.899
Annual Cooling, Dehumidification, and Enthalpy Design Conditions															
Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
1	11.0	27.9	15.8	25.8	14.7	23.9	13.8	16.7	26.1	15.6	24.2	14.6	22.4	11.5	270
Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
12.7	9.2	18.5	11.7	8.6	17.7	10.8	8.1	17.1	47.2	26.4	44.0	24.4	41.2	22.4	21.8
Extreme Annual Design Conditions															
Extreme Annual WS				Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
				Mean		Standard deviation		n=5 years		n=10 years		n=20 years		n=50 years	
				1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min
21.1	18.7	15.5	DB	-6.9	32.7	2.0	2.3	-8.3	34.4	-9.5	35.7	-10.6	37.0	-12.1	38.7
			WB	-7.3	18.8	1.9	1.1	-8.7	19.6	-9.8	20.3	-10.9	20.9	-12.3	21.8
Monthly Climatic Design Conditions															
			Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	15.6	15.3	13.5	10.3	6.9	3.8	3.5	5.2	7.8	10.2	12.7	14.7	
	DBStd	5.48	3.27	3.97	3.63	3.42	3.46	3.28	3.27	2.96	3.41	3.51	3.49	3.46	
	HDD10.0	834	1	3	8	37	108	187	202	151	83	40	11	3	
	HDD18.3	3111	96	101	156	242	355	435	458	407	317	252	171	122	
	CDD10.0	812	176	152	116	45	12	2	2	3	17	47	93	148	
	CDD18.3	48	12	17	6	1	0	0	0	0	0	1	3	9	
	CDH23.3	543	151	179	60	4	0	0	0	0	1	8	41	100	
	CDH26.7	128	35	58	11	0	0	0	0	0	0	1	6	18	
Wind		WSAvg	7.7	8.4	8.0	7.2	7.4	6.8	6.9	7.0	7.3	7.6	7.9	8.6	8.6
Precipitation	PrecAvg	240	17	22	24	18	27	27	25	19	17	19	15	22	
	PrecMax	503	44	77	106	66	66	182	104	60	62	66	49	112	
	PrecMin	115	1	1	0	0	0	1	0	1	0	0	0	0	
	PrecStd	76	11	18	27	16	18	30	28	17	15	13	12	23	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.4	32.5	28.0	23.5	18.7	14.5	14.7	16.1	20.8	24.3	27.5	29.0	
		MCWB	16.8	17.5	16.5	14.0	11.8	8.5	8.7	9.5	11.3	12.7	14.9	15.8	
	2%	DB	27.0	28.0	24.9	20.7	16.0	12.0	11.6	13.8	17.4	21.1	24.2	26.0	
		MCWB	15.3	16.0	14.3	12.7	10.0	7.4	7.0	7.9	9.5	11.4	13.5	14.3	
	5%	DB	24.6	25.2	22.2	18.5	14.3	10.2	10.1	12.0	15.7	19.0	22.0	23.8	
		MCWB	14.3	15.0	13.2	11.4	9.1	6.1	6.0	6.8	8.7	10.3	12.1	13.2	
	10%	DB	22.5	22.7	20.0	16.4	12.5	8.7	8.6	10.4	13.9	16.9	19.6	21.7	
		MCWB	13.2	14.1	12.1	10.1	7.9	5.4	4.9	5.9	7.9	9.3	10.8	12.2	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.8	18.7	17.0	14.9	12.4	9.4	9.2	10.5	12.0	13.8	15.6	17.2	
		MCDB	27.6	29.0	27.0	21.8	17.4	13.1	13.7	14.8	18.7	22.6	25.8	27.5	
	2%	WB	16.3	16.8	15.2	13.2	10.8	7.8	7.4	8.5	10.2	12.0	14.0	15.2	
		MCDB	25.2	26.3	22.8	19.7	15.1	11.1	11.2	12.8	16.3	19.5	22.9	24.0	
	5%	WB	15.0	15.7	14.0	11.9	9.6	6.7	6.3	7.4	9.2	10.9	12.7	14.0	
		MCDB	23.3	24.2	20.7	17.4	13.3	9.6	9.3	11.3	14.8	17.6	20.6	22.2	
	10%	WB	14.0	14.5	12.9	10.7	8.4	5.7	5.3	6.2	8.1	9.8	11.5	12.9	
		MCDB	21.3	21.6	18.7	15.6	11.7	8.2	7.9	9.6	13.2	16.1	18.6	20.4	

Mean Daily Temperature Range		MDBR	11.0	10.7	10.3	9.4	7.7	6.1	6.3	7.7	9.1	10.4	10.7	10.8
	5% DB	MCDBR	14.8	15.4	13.8	11.9	9.9	7.7	8.1	9.9	11.7	13.5	14.4	14.7
		MCWBR	7.1	7.0	6.8	6.8	6.3	5.2	5.3	6.0	6.6	7.1	7.1	6.8
	5% WB	MCDBR	13.8	14.2	12.0	11.2	9.0	7.0	7.6	9.4	11.0	12.5	13.6	13.7
		MCWBR	7.2	7.2	6.7	7.0	6.2	5.2	5.5	6.3	6.6	7.1	7.1	6.8
Clear Sky Solar Irradiance	taub		0.326	0.326	0.313	0.306	0.288	0.278	0.277	0.293	0.305	0.312	0.316	0.326
	taud		2.537	2.543	2.571	2.569	2.567	2.527	2.559	2.560	2.540	2.528	2.529	2.523
	Ebn at noon		987	954	914	829	751	704	755	832	907	959	991	995
	Edn at noon		104	96	83	68	53	47	52	66	84	97	104	107
All-Sky Solar Radiation	RadAvg		6.86	5.72	4.01	2.47	1.39	0.95	1.13	2.02	3.36	5.14	6.44	7.04
	RadStd		0.35	0.23	0.25	0.11	0.07	0.07	0.08	0.13	0.21	0.15	0.33	0.45
Historical Trends														
		DBAvg	Heating		Cooling			Degree-Days						
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3			
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			
Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			

CDDn	Cooling degree-days base n°C, °C-day	Lat	Latitude, °	Period	Years used to calculate the design conditions
CDHn	Cooling degree-hours base n°C, °C-hour	Long	Longitude, °	Sd	Standard deviation of daily average temperature, °C
DB	Dry bulb temperature, °C	MCDB	Mean coincident dry bulb temperature, °C	StdP	Standard pressure at station elevation, kPa
DP	Dew point temperature, °C	MCDBR	Mean coincident dry bulb temp. range, °C	taub	Clear sky optical depth for beam irradiance
Ebn,noon	Clear sky beam normal and diffuse horizontal irradiances at solar noon, W/m2	MCDP	Mean coincident dew point temperature, °C	taud	Clear sky optical depth for diffuse irradiance
Edh,noon		MCWB	Mean coincident wet bulb temperature, °C	Tavg	Average temperature, °C
Elev	Elevation, m	MCWBR	Mean coincident wet bulb temp. range, °C	Time Zone	Hours ahead or behind UTC
Enth	Enthalpy, kJ/kg	MCWS	Mean coincident wind speed, m/s	WB	Wet bulb temperature, °C
HDDn	Heating degree-days base n°C, °C-day	MDBR	Mean dry bulb temp. range, °C	Hours 8/4 & 12.8/20.6	Number of hours between 8 a.m. and 4 p.m with DB between 12.8 and 20.6 °C
PCWD	Prevailing coincident wind direction, °,0 = North, 90 = East	WS	Wind speed, m/s	HR	Humidity ratio, g of moisture per kg of dry air