

|   |                        |                 |                               |                            |      |                    |      |  |                       |            |      |                       |                       |                      |                |  |            |  |
|---|------------------------|-----------------|-------------------------------|----------------------------|------|--------------------|------|--|-----------------------|------------|------|-----------------------|-----------------------|----------------------|----------------|--|------------|--|
| 2021 ASHRAE Handbook - Fundamentals (SI)                          |                        |                 |                               |                            |      |                    |      |  |                       |            |      |                       |                       |                      |                |  |            |  |
| SAN RAFAEL, ARGENTINA (WMO: 875090)                               |                        |                 |                               |                            |      |                    |      |  |                       |            |      |                       |                       |                      |                |  |            |  |
| Lat:34.5908S  |                        |                 | Long:68.4017W                 |                            |      | Elev:748           |      |  | StdP: 92.66           |            |      | Time zone:-3.00 (W03) |                       |                      | Period:94-19   |  | WBAN:99999 |  |
| Annual Heating, Humidification, and Ventilation Design Conditions |                        |                 |                               |                            |      |                    |      |  |                       |            |      |                       |                       |                      |                |  |            |  |
| Coldest Month   | Heating DB             |                 | Humidification DP/MCDB and HR |                            |      |                    |      |  | Coldest month WS/MCDB |            |      |                       | MCWS/PCWD to 99.6% DB |                      | WSF            |  |            |  |
|   |                        |                 | 99.6%                         |                            |      | 99%                |      |  | 0.4%                  |            | 1%   |                       |                       |                      |                |  |            |  |
|   | 99.6%                  | 99%             | DP                            | HR                         | MCDB | DP                 | HR   | MCDB   | WS                    | MCDB       | WS   | MCDB                  | MCWS                  | PCWD                 |                |  |            |  |
| 7   | -2.0                   | -0.5            | -12.4                         | 1.4                        | 10.9 | -9.9               | 1.8  | 9.0  | 10.3                  | 14.0       | 8.7  | 13.6                  | 1.6                   | 270                  | 0.436          |  |            |  |
| Annual Cooling, Dehumidification, and Enthalpy Design Conditions  |                        |                 |                               |                            |      |                    |      |  |                       |            |      |                       |                       |                      |                |  |            |  |
| Hottest Month   | Hottest Month DB Range | Cooling DB/MCWB |                               |                            |      |                    |      | Evaporation WB/MCDB                                |                       |            |      |                       |                       | MCWS/PCWD to 0.4% DB |                |  |            |  |
|   |                        | 0.4%            |                               | 1%                         |      | 2%                 |      | 0.4%   |                       | 1%         |      | 2%                    |                       |                      |                |  |            |  |
|   |                        | DB              | MCWB                          | DB                         | MCWB | DB                 | MCWB | WB   | MCDB                  | WB         | MCDB | WB                    | MCDB                  | MCWS                 | PCWD           |  |            |  |
| 1   | 14.2                   | 34.9            | 19.5                          | 33.4                       | 19.1 | 31.9               | 18.5 | 22.0   | 31.2                  | 21.0       | 30.0 | 20.1                  | 28.7                  | 5.2                  | 0              |  |            |  |
| Dehumidification DP/MCDB and HR                                   |                        |                 |                               |                            |      |                    |      |  | Enthalpy/MCDB         |            |      |                       |                       |                      | Extreme Max WB |  |            |  |
| 0.4%  |                        |                 | 1%                            |                            |      | 2%                 |      |  | 0.4%                  |            | 1%   |                       | 2%                    |                      |                |  |            |  |
| DP  | HR                     | MCDB            | DP                            | HR                         | MCDB | DP                 | HR   | MCDB   | Enth                  | MCDB       | Enth | MCDB                  | Enth                  | MCDB                 |                |  |            |  |
| 19.1  | 15.3                   | 26.0            | 18.1                          | 14.2                       | 25.1 | 17.0               | 13.3 | 24.3   | 68.2                  | 31.2       | 64.3 | 30.2                  | 61.0                  | 28.8                 | 27.2           |  |            |  |
| Extreme Annual Design Conditions                                  |                        |                 |                               |                            |      |                    |      |  |                       |            |      |                       |                       |                      |                |  |            |  |
| Extreme Annual WS   |                        |                 |                               | Extreme Annual Temperature |      |                    |      | n-Year Return Period Values of Extreme Temperature |                       |            |      |                       |                       |                      |                |  |            |  |
|   |                        |                 |                               | Mean                       |      | Standard deviation |      | n=5 years  |                       | n=10 years |      | n=20 years            |                       | n=50 years           |                |  |            |  |
| 1%  | 2.5%                   | 5%              |                               | Min                        | Max  | Min                | Max  | Min  | Max                   | Min        | Max  | Min                   | Max                   | Min                  | Max            |  |            |  |
| 9.2   | 7.5                    | 6.3             | DB                            | -4.5                       | 38.1 | 1.3                | 1.6  | -5.5   | 39.3                  | -6.3       | 40.2 | -7.0                  | 41.2                  | -8.0                 | 42.4           |  |            |  |
|   |                        |                 | WB                            | -5.7                       | 24.0 | 1.2                | 1.3  | -6.5   | 25.0                  | -7.2       | 25.8 | -7.8                  | 26.5                  | -8.7                 | 27.5           |  |            |  |
| Monthly Climatic Design Conditions                                |                        |                 |                               |                            |      |                    |      |  |                       |            |      |                       |                       |                      |                |  |            |  |
|   |                        |                 | Annual                        | Jan                        | Feb  | Mar                | Apr  | May  | Jun                   | Jul        | Aug  | Sep                   | Oct                   | Nov                  | Dec            |  |            |  |
| Temperatures, Degree-Days and Degree-Hours                        | DBAvg                  | 15.9            | 23.8                          | 22.4                       | 19.8 | 15.5               | 11.8 | 9.0  | 8.2                   | 10.1       | 12.7 | 16.0                  | 19.5                  | 22.2                 |                |  |            |  |
|   | DBStd                  | 6.34            | 2.90                          | 3.45                       | 3.55 | 3.55               | 3.40 | 3.06   | 3.42                  | 3.94       | 3.80 | 3.62                  | 3.35                  | 3.23                 |                |  |            |  |
|   | HDD10.0                | 219             | 0                             | 0                          | 1    | 3                  | 19   | 54   | 74                    | 46         | 17   | 3                     | 1                     | 0                    |                |  |            |  |
|   | HDD18.3                | 1482            | 2                             | 8                          | 27   | 97                 | 202  | 282  | 313                   | 256        | 172  | 90                    | 27                    | 7                    |                |  |            |  |
|   | CDD10.0                | 2364            | 428                           | 346                        | 303  | 168                | 77   | 23   | 20                    | 50         | 98   | 188                   | 284                   | 379                  |                |  |            |  |
|   | CDD18.3                | 584             | 171                           | 121                        | 71   | 12                 | 1    | 0  | 0                     | 1          | 3    | 17                    | 61                    | 128                  |                |  |            |  |
|   | CDH23.3                | 6912            | 1924                          | 1282                       | 751  | 179                | 22   | 1  | 3                     | 43         | 94   | 303                   | 790                   | 1521                 |                |  |            |  |
|   | CDH26.7                | 2804            | 901                           | 557                        | 266  | 33                 | 3    | 0  | 0                     | 9          | 17   | 79                    | 283                   | 657                  |                |  |            |  |
| Wind  |                        | WSAvg           | 2.5                           | 2.7                        | 2.5  | 2.4                | 2.1  | 2.0  | 2.2                   | 2.4        | 2.6  | 2.6                   | 2.8                   | 2.9                  | 3.0            |  |            |  |
| Precipitation   | PrecAvg                | 336             | 54                            | 47                         | 42   | 24                 | 11   | 10   | 10                    | 15         | 24   | 31                    | 40                    | 45                   |                |  |            |  |
|   | PrecMax                | 598             | 204                           | 281                        | 178  | 92                 | 53   | 78   | 51                    | 79         | 113  | 106                   | 160                   | 168                  |                |  |            |  |
|   | PrecMin                | 107             | 2                             | 0                          | 0    | 0                  | 0    | 0  | 0                     | 0          | 0    | 0                     | 0                     | 0                    |                |  |            |  |
|   | PrecStd                | 119             | 45                            | 45                         | 37   | 26                 | 13   | 14   | 13                    | 19         | 25   | 27                    | 32                    | 35                   |                |  |            |  |
| Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures | 0.4%                   | DB              | 37.4                          | 36.2                       | 33.6 | 29.7               | 25.9 | 22.6   | 22.9                  | 27.7       | 28.9 | 31.6                  | 34.1                  | 36.4                 |                |  |            |  |
|   |                        | MCWB            | 20.6                          | 20.4                       | 19.6 | 17.2               | 14.6 | 11.7   | 10.5                  | 13.5       | 14.0 | 16.6                  | 18.0                  | 19.2                 |                |  |            |  |
|   | 2%                     | DB              | 35.1                          | 34.0                       | 31.5 | 27.5               | 23.1 | 19.8   | 20.1                  | 23.8       | 26.0 | 28.9                  | 31.9                  | 34.2                 |                |  |            |  |
|   |                        | MCWB            | 19.9                          | 19.6                       | 18.9 | 16.4               | 13.9 | 10.3   | 9.8                   | 11.9       | 13.1 | 15.6                  | 17.5                  | 18.7                 |                |  |            |  |
|   | 5%                     | DB              | 33.2                          | 32.1                       | 29.7 | 25.3               | 21.0 | 17.8   | 17.9                  | 21.0       | 23.7 | 26.7                  | 30.0                  | 32.2                 |                |  |            |  |
|   |                        | MCWB            | 19.3                          | 19.0                       | 18.4 | 15.3               | 12.9 | 9.6  | 9.0                   | 10.6       | 12.3 | 14.5                  | 16.7                  | 18.5                 |                |  |            |  |
|   | 10%                    | DB              | 31.5                          | 30.2                       | 27.8 | 23.3               | 18.8 | 15.9   | 15.6                  | 18.3       | 21.2 | 24.6                  | 28.0                  | 30.4                 |                |  |            |  |
|   |                        | MCWB            | 18.8                          | 18.6                       | 17.5 | 14.6               | 11.8 | 8.6  | 7.9                   | 9.1        | 11.2 | 13.8                  | 15.8                  | 17.5                 |                |  |            |  |
| Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures | 0.4%                   | WB              | 23.3                          | 23.2                       | 22.2 | 19.3               | 16.2 | 12.8   | 12.1                  | 14.5       | 16.1 | 19.1                  | 20.8                  | 23.0                 |                |  |            |  |
|   |                        | MCDB            | 32.8                          | 31.9                       | 30.5 | 25.7               | 23.5 | 19.9   | 20.2                  | 25.2       | 26.0 | 28.0                  | 30.3                  | 32.0                 |                |  |            |  |
|   | 2%                     | WB              | 21.7                          | 21.8                       | 20.5 | 17.7               | 14.8 | 11.3   | 10.6                  | 12.4       | 14.3 | 17.2                  | 19.1                  | 21.0                 |                |  |            |  |
|   |                        | MCDB            | 31.4                          | 30.7                       | 28.3 | 24.8               | 21.1 | 18.1   | 18.7                  | 22.7       | 23.6 | 25.9                  | 28.9                  | 30.5                 |                |  |            |  |
|   | 5%                     | WB              | 20.8                          | 20.7                       | 19.2 | 16.5               | 13.6 | 10.1   | 9.4                   | 11.0       | 13.0 | 15.8                  | 17.7                  | 19.6                 |                |  |            |  |
|   |                        | MCDB            | 30.5                          | 28.7                       | 27.4 | 23.3               | 19.1 | 16.4   | 16.8                  | 19.6       | 21.9 | 24.2                  | 27.3                  | 28.9                 |                |  |            |  |
|   | 10%                    | WB              | 19.9                          | 19.7                       | 18.2 | 15.4               | 12.4 | 9.1  | 8.2                   | 9.6        | 11.7 | 14.6                  | 16.6                  | 18.6                 |                |  |            |  |
|   |                        | MCDB            | 29.0                          | 27.4                       | 26.2 | 21.7               | 17.4 | 15.2   | 14.6                  | 17.3       | 20.0 | 22.5                  | 25.9                  | 28.0                 |                |  |            |  |

|                              |             |       |         |        |         |       |       |             |         |         |         |       |       |       |
|------------------------------|-------------|-------|---------|--------|---------|-------|-------|-------------|---------|---------|---------|-------|-------|-------|
| Mean Daily Temperature Range |             | MDBR  | 14.2    | 13.5   | 12.8    | 12.3  | 11.6  | 12.6        | 12.9    | 13.5    | 13.6    | 13.6  | 14.6  | 14.5  |
|                              | 5% DB       | MCDBR | 16.8    | 16.5   | 16.1    | 16.0  | 15.2  | 15.7        | 16.5    | 17.7    | 17.9    | 17.6  | 18.1  | 17.4  |
|                              |             | MCWBR | 6.4     | 6.2    | 6.6     | 7.6   | 7.9   | 8.8         | 8.9     | 8.8     | 8.5     | 7.9   | 7.9   | 7.1   |
|                              | 5% WB       | MCDBR | 14.7    | 13.8   | 14.0    | 13.8  | 13.2  | 14.5        | 15.1    | 16.1    | 16.1    | 15.3  | 15.8  | 15.0  |
|                              |             | MCWBR | 6.3     | 6.2    | 6.5     | 7.3   | 7.5   | 8.5         | 8.7     | 8.5     | 8.5     | 7.9   | 7.9   | 7.1   |
| Clear Sky Solar Irradiance   | taub        |       | 0.386   | 0.374  | 0.363   | 0.349 | 0.324 | 0.297       | 0.296   | 0.320   | 0.356   | 0.354 | 0.361 | 0.372 |
|                              | taud        |       | 2.361   | 2.400  | 2.426   | 2.434 | 2.467 | 2.546       | 2.517   | 2.438   | 2.338   | 2.374 | 2.370 | 2.373 |
|                              | Ebn at noon |       | 951     | 940    | 912     | 866   | 835   | 841         | 861     | 885     | 904     | 949   | 969   | 968   |
|                              | Edn at noon |       | 131     | 121    | 110     | 97    | 82    | 71          | 76      | 94      | 118     | 123   | 129   | 130   |
| All-Sky Solar Radiation      | RadAvg      |       | 8.02    | 6.99   | 5.71    | 4.23  | 2.96  | 2.64        | 2.88    | 3.78    | 5.12    | 6.41  | 7.76  | 8.31  |
|                              | RadStd      |       | 0.44    | 0.38   | 0.41    | 0.41  | 0.34  | 0.22        | 0.20    | 0.28    | 0.34    | 0.63  | 0.45  | 0.42  |
| Historical Trends            |             |       |         |        |         |       |       |             |         |         |         |       |       |       |
|                              |             | DBAvg | Heating |        | Cooling |       |       | Degree-Days |         |         |         |       |       |       |
|                              |             |       | 99% DB  | 99% DP | 1% DB   | 1% WB | 1% DP | HDD10.0     | HDD18.3 | CDD10.0 | CDD18.3 |       |       |       |
| Station Only                 |             | N/A   | N/A     | N/A    | +0.85   | N/A   | N/A   | N/A         | N/A     | N/A     | N/A     |       |       |       |
| Regional (0 neighbors)       |             | N/A   | N/A     | N/A    | +0.64   | N/A   | N/A   | N/A         | N/A     | N/A     | N/A     |       |       |       |

|          |  |       |   |                       |   |
|----------|--|-------|---|-----------------------|---|
| CDDn     | Cooling degree-days base n°C, °C-day   | Lat   | Latitude, °                               | Period                | Years used to calculate the design conditions                             |
| CDHn     | Cooling degree-hours base n°C, °C-hour                                       | Long  | Longitude, °                              | Sd                    | Standard deviation of daily average temperature, °C                       |
| DB       | Dry bulb temperature, °C   | MCDB  | Mean coincident dry bulb temperature, °C  | StdP                  | Standard pressure at station elevation, kPa                               |
| DP       | Dew point temperature, °C  | MCDBR | Mean coincident dry bulb temp. range, °C  | taub                  | Clear sky optical depth for beam irradiance                               |
| Ebn,noon | Clear sky beam normal and diffuse horizontal irradiances at solar noon, W/m2 | MCDP  | Mean coincident dew point temperature, °C | taud                  | Clear sky optical depth for diffuse irradiance                            |
| Edh,noon |  | MCWB  | Mean coincident wet bulb temperature, °C  | Tavg                  | Average temperature, °C   |
| Elev     | Elevation, m   | MCWBR | Mean coincident wet bulb temp. range, °C  | Time Zone             | Hours ahead or behind UTC   |
| Enth     | Enthalpy, kJ/kg  | MCWS  | Mean coincident wind speed, m/s           | WB                    | Wet bulb temperature, °C  |
| HDDn     | Heating degree-days base n°C, °C-day   | MDBR  | Mean dry bulb temp. range, °C             | Hours 8/4 & 12.8/20.6 | Number of hours between 8 a.m. and 4 p.m with DB between 12.8 and 20.6 °C |
| PCWD     | Prevailing coincident wind direction, °,0 = North, 90 = East                 | WS    | Wind speed, m/s                           | HR                    | Humidity ratio, g of moisture per kg of dry air                           |