

2021 ASHRAE Handbook - Fundamentals (SI)

SANTA FE, ARGENTINA (WMO: 873710)

| Lat: 31.7078S | Long: 60.8053W | Elev: 18 | StdP: 101.11 | Time zone: -3.00 (W03) | | | | Period: 94-19 | | | | WBAN: 99999 | | | | | | | | | |
|---|------------------------|-------------------------------|----------------------------|-------------------------------|--------------------|-------------|--|-----------------------|-------------|-------------|-------------|------------------------------|-------------|-------------|--------------|--|--|--|--|--|--|
| Annual Heating, Humidification, and Ventilation Design Conditions | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | |
| Coldest Month | Heating DB | Humidification DP/MCDB and HR | | | | | | Coldest month WS/MCDB | | | | MCWS/PCWD to 99.6% DB WSF | | | | | | | | | |
| | | 99.6% | | 99% | | 0.4% | | 1% | | | | | | | | | | | | | |
| | 99.6% | 99% | DP | HR | MCDB | DP | HR | MCDB | WS | MCDB | WS | MCDB | MCWS PCWD | | | | | | | | |
| 7 | 0.9 | 2.9 | -3.1 | 2.9 | 6.5 | -1.4 | 3.4 | 6.7 | 16.2 | 12.6 | 14.5 | 14.8 | 1.0 | 230 | 0.407 | | | | | | |
| Annual Cooling, Dehumidification, and Enthalpy Design Conditions | | | | | | | | | | | | | | | | | | | | | |
| Hottest Month | Hottest Month DB Range | Cooling DB/MCWB | | | | | | Evaporation WB/MCDB | | | | MCWS/PCWD to 0.4% DB | | | | | | | | | |
| | | 0.4% | | 1% | | 2% | | 0.4% | | 1% | | | | | | | | | | | |
| | DB | MCWB | DB | MCWB | DB | MCWB | WB | MCDB | WB | MCDB | WB | MCDB | MCWS PCWD | | | | | | | | |
| 1 | 10.3 | 35.1 | 24.2 | 33.6 | 23.5 | 32.2 | 23.0 | 26.4 | 32.0 | 25.5 | 30.9 | 24.7 | 29.8 | 5.4 | 0 | | | | | | |
| Dehumidification DP/MCDB and HR | | | | | | | | | | | | | | | | | | | | | |
| 0.4% | | 1% | | 2% | | 0.4% | | 1% | | 2% | | Extreme Max WB | | | | | | | | | |
| DP | HR | MCDB | DP | HR | MCDB | DP | HR | MCDB | Enth | MCDB | Enth | MCDB | | | | | | | | | |
| 24.9 | 20.0 | 29.8 | 24.0 | 18.9 | 28.8 | 23.1 | 17.9 | 27.9 | 82.6 | 32.0 | 78.7 | 31.0 | 75.1 | 30.0 | 30.2 | | | | | | |
| Extreme Annual Design Conditions | | | | | | | | | | | | | | | | | | | | | |
| Extreme Annual WS | | | Extreme Annual Temperature | | | | n-Year Return Period Values of Extreme Temperature | | | | | | | | | | | | | | |
| | | | Mean | | Standard deviation | | n=5 years | | n=10 years | | n=20 years | | n=50 years | | | | | | | | |
| 1% | 2.5% | 5% | Min | Max | Min | Max | Min | Max | Min | Max | Min | Max | Min | Max | | | | | | | |
| 14.4 | 12.0 | 10.3 | DB | -2.3 | 38.6 | 1.7 | 1.4 | -3.5 | 39.6 | -4.5 | 40.5 | -5.5 | 41.3 | -6.8 | 42.3 | | | | | | |
| | | | WB | -2.9 | 28.0 | 1.6 | 0.9 | -4.1 | 28.7 | -5.0 | 29.2 | -5.9 | 29.8 | -7.1 | 30.5 | | | | | | |
| Monthly Climatic Design Conditions | | | | | | | | | | | | | | | | | | | | | |
| | | | Annual | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | | | | | | |
| Temperatures, Degree-Days and Degree-Hours | DBAvg | 19.1 | 25.8 | 24.6 | 22.6 | 19.2 | 15.9 | 12.9 | 12.2 | 14.2 | 16.5 | 19.4 | 22.3 | 24.5 | | | | | | | |
| | | 5.89 | 2.72 | 2.96 | 3.12 | 3.68 | 3.96 | 4.00 | 4.47 | 4.73 | 4.16 | 3.54 | 3.13 | 2.96 | | | | | | | |
| | HDD10.0 | 52 | 0 | 0 | 0 | 0 | 2 | 13 | 24 | 10 | 2 | 0 | 0 | 0 | | | | | | | |
| | HDD18.3 | 769 | 0 | 1 | 4 | 32 | 97 | 171 | 199 | 149 | 83 | 28 | 5 | 1 | | | | | | | |
| | CDD10.0 | 3389 | 491 | 408 | 390 | 276 | 187 | 100 | 93 | 139 | 196 | 293 | 368 | 449 | | | | | | | |
| | CDD18.3 | 1066 | 233 | 176 | 136 | 58 | 23 | 8 | 9 | 20 | 27 | 62 | 123 | 191 | | | | | | | |
| | CDH23.3 | 9404 | 2433 | 1586 | 1062 | 362 | 104 | 24 | 44 | 159 | 231 | 476 | 1062 | 1861 | | | | | | | |
| | CDH26.7 | 3553 | 1072 | 612 | 348 | 89 | 19 | 3 | 9 | 50 | 71 | 142 | 369 | 768 | | | | | | | |
| Wind | | WSAvg | 3.4 | 2.9 | 2.9 | 2.8 | 2.9 | 2.9 | 3.4 | 3.6 | 4.1 | 4.1 | 4.1 | 4.0 | 3.5 | | | | | | |
| Precipitation | | PrecAvg | 991 | 110 | 106 | 143 | 102 | 48 | 31 | 27 | 34 | 53 | 100 | 118 | 107 | | | | | | |
| | | PrecMax | 1654 | 276 | 415 | 408 | 392 | 154 | 184 | 81 | 196 | 218 | 313 | 290 | 331 | | | | | | |
| | | PrecMin | 496 | 4 | 3 | 20 | 6 | 1 | 0 | 0 | 0 | 4 | 28 | 14 | 11 | | | | | | |
| | | PrecStd | 229 | 78 | 79 | 82 | 79 | 42 | 37 | 21 | 39 | 48 | 60 | 65 | 73 | | | | | | |
| Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures | | 0.4% | DB | 37.6 | 35.7 | 34.1 | 31.8 | 29.1 | 26.3 | 27.8 | 31.6 | 33.0 | 33.6 | 34.7 | 36.5 | | | | | | |
| | | | MCWB | 24.9 | 25.0 | 24.8 | 23.6 | 22.0 | 21.0 | 19.8 | 21.7 | 22.3 | 22.7 | 23.2 | 23.6 | | | | | | |
| | | 2% | DB | 35.1 | 33.7 | 31.9 | 29.1 | 26.0 | 23.0 | 23.8 | 27.4 | 28.4 | 30.1 | 32.2 | 34.3 | | | | | | |
| | | | MCWB | 24.4 | 24.4 | 23.4 | 21.8 | 20.1 | 19.1 | 18.6 | 19.6 | 19.9 | 21.4 | 21.7 | 23.5 | | | | | | |
| | | 5% | DB | 33.3 | 32.0 | 30.1 | 27.1 | 23.9 | 20.9 | 21.0 | 24.4 | 25.9 | 27.9 | 30.5 | 32.6 | | | | | | |
| | | | MCWB | 23.6 | 24.0 | 22.7 | 21.0 | 19.4 | 17.5 | 16.6 | 17.9 | 18.7 | 20.3 | 21.0 | 22.7 | | | | | | |
| | | 10% | DB | 31.9 | 30.5 | 28.5 | 25.2 | 21.9 | 18.9 | 19.0 | 21.8 | 23.6 | 25.9 | 28.7 | 30.8 | | | | | | |
| | | | MCWB | 23.2 | 23.3 | 21.9 | 20.0 | 18.0 | 16.0 | 15.4 | 16.4 | 17.1 | 19.1 | 20.5 | 22.2 | | | | | | |
| Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures | | 0.4% | WB | 27.3 | 27.4 | 26.8 | 25.0 | 22.8 | 21.7 | 21.0 | 22.3 | 23.3 | 25.1 | 25.2 | 26.8 | | | | | | |
| | | | MCDB | 33.8 | 32.6 | 31.4 | 29.8 | 27.2 | 25.0 | 25.9 | 29.0 | 30.0 | 31.5 | 31.6 | 33.5 | | | | | | |
| | | 2% | WB | 26.2 | 26.2 | 25.1 | 23.6 | 21.3 | 19.9 | 19.1 | 20.4 | 21.1 | 22.9 | 23.5 | 25.5 | | | | | | |
| | | | MCDB | 32.2 | 31.1 | 29.3 | 27.3 | 24.6 | 22.2 | 22.8 | 26.3 | 27.0 | 27.6 | 29.2 | 31.2 | | | | | | |
| | | 5% | WB | 25.3 | 25.2 | 23.8 | 22.2 | 20.1 | 18.3 | 17.6 | 19.0 | 19.5 | 21.5 | 22.5 | 24.4 | | | | | | |
| | | | MCDB | 31.1 | 29.8 | 28.0 | 25.2 | 23.0 | 20.4 | 20.5 | 23.6 | 24.2 | 26.0 | 27.9 | 29.7 | | | | | | |
| | | 10% | WB | 24.4 | 24.2 | 22.8 | 21.1 | 18.8 | 16.7 | 16.0 | 17.1 | 18.0 | 20.2 | 21.5 | 23.3 | | | | | | |
| | | | MCDB | 29.8 | 28.9 | 27.1 | 24.1 | 21.3 | 18.4 | 18.3 | 20.8 | 22.3 | 24.6 | 26.7 | 28.5 | | | | | | |

| | | | | | | | | | | | | | | | |
|-------------------------------|-------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|-------------|--|
| Mean Daily Temperature Range | | MDBR | 10.3 | 9.6 | 9.9 | 9.6 | 9.0 | 9.3 | 10.0 | 10.8 | 10.8 | 10.1 | 10.7 | 10.5 | |
| | 5% DB | MCDBR | 12.6 | 11.8 | 11.6 | 12.0 | 10.7 | 10.4 | 11.6 | 13.4 | 13.9 | 12.9 | 13.3 | 13.2 | |
| | | MCWBR | 4.9 | 4.9 | 5.0 | 5.9 | 5.6 | 6.2 | 6.5 | 6.9 | 6.9 | 6.1 | 5.5 | 5.4 | |
| | 5% WB | MCDBR | 10.4 | 9.7 | 9.9 | 9.3 | 8.8 | 8.1 | 9.8 | 11.9 | 11.4 | 10.6 | 10.7 | 10.5 | |
| | | MCWBR | 5.1 | 5.1 | 5.2 | 5.6 | 5.1 | 5.4 | 6.0 | 6.5 | 6.9 | 6.1 | 5.5 | 5.4 | |
| Clear Sky Solar Irradiance | taub | 0.403 | 0.393 | 0.377 | 0.385 | 0.364 | 0.355 | 0.359 | 0.427 | 0.490 | 0.433 | 0.397 | 0.400 | | |
| | taud | 2.374 | 2.418 | 2.455 | 2.399 | 2.414 | 2.430 | 2.392 | 2.151 | 1.982 | 2.221 | 2.347 | 2.366 | | |
| | Ebn at noon | 937 | 927 | 907 | 841 | 806 | 788 | 802 | 780 | 782 | 879 | 936 | 943 | | |
| | Edn at noon | 130 | 120 | 109 | 104 | 91 | 85 | 92 | 130 | 172 | 145 | 133 | 132 | | |
| All-Sky Solar Radiation | RadAvg | 7.15 | 6.15 | 5.27 | 3.88 | 2.89 | 2.50 | 2.79 | 3.71 | 4.80 | 5.69 | 6.91 | 7.24 | | |
| | RadStd | 0.46 | 0.46 | 0.42 | 0.49 | 0.25 | 0.28 | 0.29 | 0.33 | 0.42 | 0.46 | 0.39 | 0.42 | | |
| Historical Trends | | | | | | | | | | | | | | | |
| | DBAvg | Heating | | Cooling | | | Degree-Days | | | | | | | | |
| | | 99% DB | 99% DP | 1% DB | 1% WB | 1% DP | HDD10.0 | HDD18.3 | CDD10.0 | CDD18.3 | | | | | |
| Station Only | | N/A | N/A | |
| Regional (0 neighbors) | | N/A | N/A | N/A | +0.23 | +0.49 | +0.55 | N/A | N/A | N/A | N/A | N/A | N/A | N/A | |

| | | | | | |
|----------|---|-------|---|--------------------------|---|
| CDDn | Cooling degree-days base n°C, °C-day | Lat | Latitude, ° | Period | Years used to calculate the design conditions |
| CDHn | Cooling degree-hours base n°C, °C-hour | Long | Longitude, ° | Sd | Standard deviation of daily average temperature, °C |
| DB | Dry bulb temperature, °C | MCDB | Mean coincident dry bulb temperature, °C | StdP | Standard pressure at station elevation, kPa |
| DP | Dew point temperature, °C | MCDBR | Mean coincident dry bulb temp. range, °C | taub | Clear sky optical depth for beam irradiance |
| Ebn,noon | Clear sky beam normal and diffuse horizontal irradiances at solar noon, | MCDP | Mean coincident dew point temperature, °C | taud | Clear sky optical depth for diffuse irradiance |
| Edh,noon | W/m2 | MCWB | Mean coincident wet bulb temperature, °C | Tavg | Average temperature, °C |
| Elev | Elevation, m | MCWBR | Mean coincident wet bulb temp. range, °C | Time Zone | Hours ahead or behind UTC |
| Enth | Enthalpy, kJ/kg | MCWS | Mean coincident wind speed, m/s | WB | Wet bulb temperature, °C |
| HDDn | Heating degree-days base n°C, °C-day | MDBR | Mean dry bulb temp. range, °C | Hours 8/4 & 12.8/20.6 °C | Number of hours between 8 a.m. and 4 p.m with DB between 12.8 and 20.6 °C |
| PCWD | Prevailing coincident wind direction, °,0 = North, 90 = East | WS | Wind speed, m/s | HR | Humidity ratio, g of moisture per kg of dry air |