

2021 ASHRAE Handbook - Fundamentals (SI)

TARTAGAL, ARGENTINA (WMO: 870220)

Lat:22.6167S	Long:63.7967W	Elev:450	StdP: 96.03	Time zone:-3.00 (W03)				Period:94-19				WBAN:99999											
Annual Heating, Humidification, and Ventilation Design Conditions																							
Coldest Month	Heating DB	Humidification DP/MCDB and HR						Coldest month WS/MCDB				MCWS/PCWD to 99.6% DB WSF											
		99.6%			99%			0.4%		1%													
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD									
7	4.7	6.5	-4.4	2.7	14.5	-2.0	3.4	15.3	10.2	21.6	9.0	20.0	0.6	270	0.308								
Annual Cooling, Dehumidification, and Enthalpy Design Conditions																							
Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB				MCWS/PCWD to 0.4% DB											
		0.4%		1%		2%		0.4%		1%													
	DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD									
1	10.2	38.1	22.4	36.5	22.6	35.1	22.6	26.1	32.1	25.5	31.5	25.0	31.0	4.9	50								
Dehumidification DP/MCDB and HR								Enthalpy/MCDB						Extreme Max WB									
0.4%		1%		2%		0.4%		1%		2%													
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth										
24.5	20.6	29.0	23.9	19.9	28.4	23.4	19.2	27.8	84.0	31.8	81.6	31.8	79.3	31.1	29.1								
Extreme Annual Design Conditions																							
Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature																
			Mean		Standard deviation		n=5 years		n=10 years		n=20 years		n=50 years										
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max									
9.3	8.0	6.8	DB	1.6	41.1	1.7	1.3	0.4	42.0	-0.6	42.8	-1.6	43.5	-2.9	44.4								
			WB	0.4	27.5	1.6	0.9	-0.7	28.1	-1.6	28.6	-2.5	29.1	-3.7	29.8								
Monthly Climatic Design Conditions																							
		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec									
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.0	26.5	25.8	23.9	21.3	18.2	16.1	15.7	18.5	21.4	24.7	25.5	26.1									
		5.31	2.73	2.75	2.97	3.48	3.54	3.57	4.09	4.70	4.58	4.10	3.62	3.18									
	HDD10.0	7	0	0	0	0	1	2	4	1	0	0	0	0									
	HDD18.3	331	0	0	2	12	47	85	102	58	21	4	1	0									
	CDD10.0	4374	511	442	432	339	255	186	182	264	343	457	465	499									
	CDD18.3	1657	253	208	175	102	43	19	21	63	114	202	216	241									
	CDH23.3	15803	2549	1854	1254	618	213	95	187	666	1256	2232	2353	2526									
	CDH26.7	7204	1199	798	455	191	40	14	45	278	591	1149	1202	1242									
Wind		WSAvg	2.0	1.9	1.8	1.7	1.5	1.5	1.6	1.8	2.2	2.5	2.6	2.5	2.2								
Precipitation		PrecAvg	993	188	192	162	64	25	9	4	4	18	48	111	168								
		PrecMax	1500	385	390	391	190	94	40	17	23	61	148	199	394								
		PrecMin	642	47	55	37	8	1	0	0	0	8	17	37									
		PrecStd	200	78	75	88	41	20	9	5	7	18	28	45	91								
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures		0.4%	DB	38.2	37.3	34.7	32.4	30.1	28.4	30.5	35.5	38.1	40.2	39.9	38.9								
			MCWB	23.1	24.1	24.2	22.8	22.4	20.3	19.5	20.0	20.6	21.6	22.7	23.0								
		2%	DB	36.1	34.9	32.9	30.9	27.6	26.0	27.8	32.7	35.5	37.5	37.4	36.8								
			MCWB	23.4	24.2	24.6	23.1	21.3	19.4	19.2	19.8	20.0	21.8	22.6	23.2								
		5%	DB	34.4	33.2	31.2	29.2	25.8	23.8	25.4	30.0	33.1	35.3	35.3	34.9								
			MCWB	23.8	24.4	24.3	22.9	20.2	18.2	17.4	18.5	19.4	21.7	22.3	23.5								
		10%	DB	32.8	31.5	29.3	27.2	23.8	21.9	23.0	27.4	30.4	33.0	33.1	33.0								
			MCWB	23.7	24.1	23.6	22.3	19.5	17.2	16.0	17.2	18.5	21.0	21.9	23.2								
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures		0.4%	WB	26.5	27.1	26.3	25.4	23.4	21.7	21.2	22.0	23.1	25.0	25.9	26.2								
			MCDB	32.5	33.0	31.4	30.1	28.0	26.1	27.8	31.7	33.4	35.7	34.8	32.9								
		2%	WB	25.7	26.0	25.5	24.4	22.4	20.5	19.8	20.6	21.7	23.8	24.7	25.4								
			MCDB	31.8	31.5	30.5	28.8	26.3	24.4	26.4	30.1	31.7	33.2	32.9	32.2								
		5%	WB	25.1	25.3	24.9	23.6	21.3	19.4	18.5	19.4	20.6	22.7	23.9	24.7								
			MCDB	31.3	30.7	29.5	27.6	24.4	22.6	23.7	28.5	29.8	31.8	31.3	31.5								
		10%	WB	24.5	24.6	24.1	22.8	20.3	18.3	17.2	18.2	19.5	21.8	23.0	24.1								
			MCDB	30.4	29.7	28.2	26.1	22.9	20.8	21.7	26.2	28.4	30.2	30.2	30.6								

Mean Daily Temperature Range		MDBR	10.2	9.3	8.1	7.6	7.8	8.7	11.0	12.6	12.5	11.5	11.2	10.4	
	5% DB	MCDBR	13.3	12.4	11.1	11.0	10.6	11.5	14.7	16.5	16.6	15.7	15.4	14.1	
		MCWBR	4.0	4.4	4.4	4.8	5.0	5.8	7.1	6.7	6.4	5.1	4.8	4.3	
	5% WB	MCDBR	10.9	10.4	9.6	9.1	8.4	9.7	13.1	14.8	13.4	13.1	12.6	11.5	
Clear Sky Solar Irradiance		taub	0.413	0.406	0.401	0.385	0.368	0.335	0.343	0.414	0.494	0.485	0.425	0.419	
		taud	2.390	2.420	2.437	2.453	2.431	2.509	2.457	2.235	2.024	2.118	2.315	2.356	
		Ebn at noon	933	926	904	876	849	863	867	832	805	844	916	928	
		Edn at noon	129	123	116	105	99	88	95	129	172	164	138	134	
All-Sky Solar Radiation	RadAvg	6.13	5.63	4.70	3.83	3.18	3.01	3.65	4.53	5.13	5.34	5.82	5.92		
	RadStd	0.49	0.33	0.46	0.43	0.40	0.31	0.31	0.35	0.48	0.48	0.59	0.48		
Historical Trends															
	DBAvg	Heating		Cooling			Degree-Days								
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3					
Station Only		N/A	N/A	N/A	+0.56	N/A									
Regional (0 neighbors)		N/A	N/A	N/A	+0.56	N/A									

CDDn	Cooling degree-days base n°C, °C-day	Lat	Latitude, °	Period	Years used to calculate the design conditions
CDHn	Cooling degree-hours base n°C, °C-hour	Long	Longitude, °	Sd	Standard deviation of daily average temperature, °C
DB	Dry bulb temperature, °C	MCDB	Mean coincident dry bulb temperature, °C	StdP	Standard pressure at station elevation, kPa
DP	Dew point temperature, °C	MCDBR	Mean coincident dry bulb temp. range, °C	taub	Clear sky optical depth for beam irradiance
Ebn,noon	Clear sky beam normal and diffuse horizontal irradiances at solar noon,	MCDP	Mean coincident dew point temperature, °C	taud	Clear sky optical depth for diffuse irradiance
Edh,noon	W/m2	MCWB	Mean coincident wet bulb temperature, °C	Tavg	Average temperature, °C
Elev	Elevation, m	MCWBR	Mean coincident wet bulb temp. range, °C	Time Zone	Hours ahead or behind UTC
Enth	Enthalpy, kJ/kg	MCWS	Mean coincident wind speed, m/s	WB	Wet bulb temperature, °C
HDDn	Heating degree-days base n°C, °C-day	MDBR	Mean dry bulb temp. range, °C	Hours 8/4 & 12.8/20.6 °C	Number of hours between 8 a.m. and 4 p.m with DB between 12.8 and 20.6 °C
PCWD	Prevailing coincident wind direction, °,0 = North, 90 = East	WS	Wind speed, m/s	HR	Humidity ratio, g of moisture per kg of dry air